



Multi-Agency Requirements

I. **No Conflict of Interest**

Agency must be able to provide independent, third party thermal performance tests and not have a vested interest in the results of any test.

II. **Testing Supervisor**

The primary tester for the agency is the Testing Supervisor, who possesses all the necessary qualifications. In addition, the agency must have a staff of qualified testers who can perform a test, if the Testing Supervisor is not available.

III. **Cooling Tower Testing Experience**

Provide information such as cooling tower size, type and number of tests conducted.

IV. **Financial Stability**

Agency must be financially stable, poses the financial resources to support an adequate staff of testing personnel, purchase, and maintain the required equipment, and not be burdened by 60-90 day payment terms.

V. **Equipment and Calibration Requirements**

Need to meet minimum amount of equipment requirements as defined in the Test Manual including required calibration intervals.