

AONE B&C ACT-C R1

Condition Reference #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
Wet Bulb ° C	13	13	13	13	13	16	16	16	16	16	18	18	18	18	18	21	21	21	21	21	24	24	24	24	24
Range ° C	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8
Approach ° C	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6
Inlet Process Temperature ° C	23	25	26	28	27	26	28	29	31	30	28	30	31	33	32	31	33	34	36	35	34	36	37	39	38
Outlet Process Temperature ° C	17	19	20	21	19	20	22	23	24	22	22	24	25	26	24	25	27	28	29	27	28	30	31	32	30
ACT-C-75-A in l/s	5.85	8.25	9.54	9.76	6.85	6.70	9.48	10.96	11.14	7.70	7.37	10.32	11.99	12.33	8.52	8.38	12.00	13.96	14.55	10.22	9.78	14.22	16.45	16.95	11.89
ACT-C-100-A in l/s	7.80	11.01	12.72	13.02	9.13	8.94	12.61	14.62	14.85	10.27	9.82	13.76	15.98	16.44	11.36	11.17	16.01	18.62	19.40	13.63	13.04	18.96	21.93	22.60	15.86
ACT-C-110-A in l/s	8.58	12.11	13.99	14.32	10.04	9.83	13.91	16.08	16.34	11.30	10.80	15.13	17.58	18.09	12.50	12.28	17.61	20.48	21.34	14.99	14.35	20.86	24.12	24.86	17.44
ACT-C-120-A in l/s	9.36	13.21	15.26	15.62	10.95	10.72	15.17	17.54	17.82	12.32	11.79	16.51	19.18	19.73	13.63	13.40	19.21	22.34	23.28	16.35	15.65	22.75	26.31	27.12	19.03
ACT-C-130-A in l/s	10.14	14.31	16.53	16.92	11.87	11.62	16.44	19.00	19.31	13.35	12.77	17.89	20.78	21.37	14.77	14.52	20.81	24.21	25.22	17.72	16.95	24.65	28.51	29.38	20.61

AONE B&C ACT-C R1

Condition Reference #	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44
Wet Bulb ° C	27	27	27	27	27	29	29	29	29	29	32	32	32	32	32	21	25.56	27	28
Range ° C	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	5	6.67	5	5
Approach ° C	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	6	6.67	5	4
Inlet Process Temperature ° C	37	39	40	42	41	39	41	42	44	43	42	44	45	47	46	32	38.90	37	37
Outlet Process Temperature ° C	31	33	34	35	33	33	35	36	37	35	36	38	39	40	38	27	32.23	32	32
ACT-C-75-A in l/s	11.72	16.57	18.49	19.31	13.37	13.01	17.72	21.15	21.98	15.35	15.62	20.82	24.06	24.83	17.45	13.69	15.64	16.25	14.08
ACT-C-100-A in l/s	15.63	22.10	24.65	25.75	17.82	17.34	23.63	28.20	29.30	20.46	20.82	27.76	32.08	33.11	23.27	18.25	20.85	21.67	18.77
ACT-C-110-A in l/s	17.19	24.31	27.12	28.33	19.60	19.08	25.99	31.02	32.23	22.51	22.90	30.54	35.29	36.42	25.60	20.08	22.93	23.83	20.65
ACT-C-120-A in l/s	18.75	26.52	29.58	30.90	21.39	20.81	28.35	33.84	35.16	24.56	24.99	33.31	38.50	39.73	27.93	21.90	25.02	26.00	22.53
ACT-C-130-A in l/s	20.32	28.73	32.05	33.48	23.17	22.55	30.72	36.66	38.09	26.60	27.07	36.09	41.71	43.04	30.25	23.73	27.10	28.17	24.40