

**Axima ACC R1, 2016**

Condition Reference #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
Wet Bulb °C	10	10	10	10	10	13	13	13	13	13	16	16	16	16	16	18	18	18	18	18	21	21	21	21	21
Range °C	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8
Approach °C	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7
Inlet Water Temperature °C	20	22	23	22	25	23	25	26	25	28	26	28	29	28	31	28	30	31	30	33	31	33	34	33	36
Outlet Water Temperature °C	14	16	17	14	17	17	19	20	17	20	20	22	23	20	23	22	24	25	22	25	25	27	28	25	28
ACC-180/05 in m3/h	14.3	20.1	23.2	12.1	19.1	16.3	23.0	26.6	13.8	21.9	18.7	26.4	30.5	15.9	25.2	20.6	29.1	33.6	17.5	27.8	23.8	33.6	38.9	20.2	32.2
ACC-430/05 in m3/h	21.1	29.7	34.2	17.8	28.2	24.0	33.9	39.2	20.3	32.3	27.6	38.9	45.0	23.4	37.2	30.3	42.8	49.5	25.7	41.0	35.1	49.6	57.3	29.8	47.5
ACC-680/05 in m3/h	32.0	45.0	52.0	27.0	42.8	36.5	51.4	59.4	30.8	49.0	41.9	59.1	68.3	35.5	56.5	46.1	65.0	75.1	39.0	62.2	53.3	75.2	87.0	45.2	72.1
ACC-930/05 in m3/h	35.4	49.8	57.5	29.8	47.3	40.4	56.9	65.7	34.1	54.2	46.3	65.4	75.5	39.2	62.4	50.9	71.9	83.1	43.2	68.8	58.9	83.2	96.2	50.0	79.8
ACC-1180/05 in m3/h	42.1	59.3	68.5	35.6	56.4	48.1	67.8	78.3	40.6	64.6	55.2	77.9	90.0	46.7	74.4	60.7	85.7	99.0	51.4	81.9	70.2	99.1	114.6	59.6	95.1

Condition Reference #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
Wet Bulb °C	10	10	10	10	10	13	13	13	13	13	16	16	16	16	16	18	18	18	18	18	21	21	21	21	21
Range °C	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8
Approach °C	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7
Inlet Water Temperature °C	20	22	23	22	25	23	25	26	25	28	26	28	29	28	31	28	30	31	30	33	31	33	34	33	36
Outlet Water Temperature °C	14	16	17	14	17	17	19	20	17	20	20	22	23	20	23	22	24	25	22	25	25	27	28	25	28
ACC-180/05 in l/s	4.0	5.6	6.5	3.4	5.3	4.5	6.4	7.4	3.8	6.1	5.2	7.3	8.5	4.4	7.0	5.7	8.1	9.3	4.8	7.7	6.6	9.3	10.8	5.6	9.0
ACC-430/05 in l/s	5.9	8.2	9.5	4.9	7.8	6.7	9.4	10.9	5.6	9.0	7.7	10.8	12.5	6.5	10.3	8.4	11.9	13.7	7.1	11.4	9.8	13.8	15.9	8.3	13.2
ACC-680/05 in l/s	8.9	12.5	14.4	7.5	11.9	10.1	14.3	16.5	8.6	13.6	11.6	16.4	19.0	9.9	15.7	12.8	18.1	20.9	10.8	17.3	14.8	20.9	24.2	12.6	20.0
ACC-930/05 in l/s	9.8	13.8	16.0	8.3	13.2	11.2	15.8	18.3	9.5	15.1	12.9	18.2	21.0	10.9	17.3	14.1	20.0	23.1	12.0	19.1	16.4	23.1	26.7	13.9	22.2
ACC-1180/05 in l/s	11.7	16.5	19.0	9.9	15.7	13.4	18.8	21.8	11.3	18.0	15.3	21.6	25.0	13.0	20.7	16.9	23.8	27.5	14.3	22.8	19.5	27.5	31.8	16.6	26.4

**Axima ACC RI, 2016**

Condition Reference #	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49
Wet Bulb °C	24	24	24	24	24	27	27	27	27	27	29	29	29	29	29	32.2	32.2	32.2	32.2	32.2	21	25.56	27	28
Range °C	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	5	5.56	5	5
Approach °C	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	6	3.89	5	4
Inlet Water Temperature °C	34	36	37	36	39	37	39	40	39	42	39	41	42	41	44	42.2	44.2	45.2	44.2	47.2	32	35.00	37	37
Outlet Water Temperature °C	28	30	31	28	31	31	33	34	31	34	33	35	36	33	36	36.2	38.2	39.2	36.2	39.2	27	29.44	32	32
ACC-180/05 in m3/h	27.7	39.1	45.2	23.5	37.6	32.3	45.6	52.7	27.5	43.9	35.8	50.6	58.5	30.5	48.8	42.5	60.0	69.4	36.3	57.9	38.1	30.6	43.6	38
ACC-430/05 in m3/h	40.8	57.6	66.6	34.7	55.3	47.6	67.2	77.7	40.5	64.7	52.8	74.6	86.3	45.0	71.9	62.6	88.4	102.3	53.4	85.4	56.2	45.1	64.3	56
ACC-680/05 in m3/h	61.9	87.4	101.1	52.6	84.0	72.2	102.0	117.9	61.5	98.1	80.1	113.2	130.9	68.3	109.1	95.0	134.2	155.2	81.1	129.6	85.2	68.5	97.6	85
ACC-930/05 in m3/h	68.5	96.7	111.8	58.2	92.9	79.8	112.8	130.4	68.0	108.5	88.6	125.2	144.8	75.5	120.6	105.1	148.4	171.6	89.7	143.3	94.3	75.7	107.9	94
ACC-1180/05 in m3/h	81.6	115.2	133.2	69.3	110.7	95.1	134.3	155.4	81.0	129.3	105.6	149.1	172.5	90.0	143.7	125.2	176.8	204.5	106.9	170.8	112.3	90.2	128.6	112

Condition Reference #	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49
Wet Bulb °C	24	24	24	24	24	27	27	27	27	27	29	29	29	29	29	32.2	32.2	32.2	32.2	32.2	21	25.56	27	28
Range °C	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	5	5.56	5	5
Approach °C	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	6	3.89	5	4
Inlet Water Temperature °C	34	36	37	36	39	37	39	40	39	42	39	41	42	41	44	42.2	44.2	45.2	44.2	47.2	32	35.00	37	37
Outlet Water Temperature °C	28	30	31	28	31	31	33	34	31	34	33	35	36	33	36	36.2	38.2	39.2	36.2	39.2	27	29.44	32	32
ACC-180/05 in l/s	7.7	10.9	12.6	6.5	10.4	9.0	12.7	14.6	7.6	12.2	10.0	14.1	16.3	8.5	13.5	11.8	16.7	19.3	10.1	16.1	10.6	8.5	12.1	10.6
ACC-430/05 in l/s	11.3	16.0	18.5	9.6	15.4	13.2	18.7	21.6	11.2	18.0	14.7	20.7	24.0	12.5	20.0	17.4	24.6	28.4	14.8	23.7	15.6	12.5	17.9	15.6
ACC-680/05 in l/s	17.2	24.3	28.1	14.6	23.3	20.1	28.3	32.8	17.1	27.3	22.3	31.4	36.4	19.0	30.3	26.4	37.3	43.1	22.5	36.0	23.7	19.0	27.1	23.6
ACC-930/05 in l/s	19.0	26.9	31.1	16.2	25.8	22.2	31.3	36.2	18.9	30.1	24.6	34.8	40.2	21.0	33.5	29.2	41.2	47.7	24.9	39.8	26.2	21.0	30.0	26.1
ACC-1180/05 in l/s	22.7	32.0	37.0	19.3	30.7	26.4	37.3	43.2	22.5	35.9	29.3	41.4	47.9	25.0	39.9	34.8	49.1	56.8	29.7	47.4	31.2	25.1	35.7	31.1