

Baltimore Aircoil Company, Inc.
FXT Line of CTI Certified Cooling Towers
CTI Certification Validation Number 92-11-01
September 22, 2006 (Revision 2)

FXT-6	FXT-16	FXT-38	FXT-74-FM	FXT-160-HM
FXT-7.5	FXT-16-CM	FXT-42	FXT-74	FXT-160
FXT-7.5-CM	FXT-20	FXT-47	FXT-87	FXT-175
	FXT-20-EM	FXT-47-HM	FXT-95	FXT-192
FXT-11	FXT-26-CM	FXT-58-EM	FXT-115-GM	FXT-216-JM
FXT-11-CM	FXT-26	FXT-58-FM	FXT-115	FXT-216
FXT-11-DM	FXT-30	FXT-58	FXT-130	FXT-240
	FXT-33	FXT-68	FXT-136	FXT-257

FXT Optional Accessories and Constructions B Certification Status

Construction Options	Suffix (Note 1)	CTI Certified	Capacity Adjustment Required
Multiple Cells	None	Yes	No, Note 2
Non-Standard Motor Size	M	Note 3	Yes, Note 3
Not CTI Certified	X	No	Note 4

- Notes:
1. Typically no suffix is used for an accessory or modification that does not affect capacity.
 2. Multiple cell models of the single cell models above are also available but not individually listed (e.g. two cells of an FXT-115 is marketed as an FXT-230).
 3. Units with non-standard motor sizes are certified only if they are listed in the Data of Record and sold at the revised capacity listed in the rating table.
 4. This suffix is affixed to model numbers of units that are not CTI Certified, due either to application or product accessories or modifications to the tower (e.g. FXT-11X).