

Cenk LEON CCCT Range (R0)

Condition Reference #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
Wet Bulb °C	10	10	10	10	10	13	13	13	13	13	16	16	16	16	16	18	18	18	18	18	21	21	21	21	21	24	24	24
Range °C	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6
Approach °C	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7
Inlet Process Temperature °C	20	22	23	25	24	23	25	26	28	27	26	28	29	31	30	28	30	31	33	32	31	33	34	36	35	34	36	37
Outlet Process Temperature °C	14	16	17	18	16	17	19	20	21	19	20	22	23	24	22	22	24	25	26	24	25	27	28	29	27	28	30	31
Process Fluid Type	WATER																											
CNK CCCT A.06.01	2.2	3.1	3.5	3.5	2.4	2.3	3.3	3.8	3.8	2.6	3.5	4.0	4.0	2.8	2.6	3.7	4.2	4.2	3.0	2.8	4.0	4.5	4.5	3.2	3.1	4.3	4.8	4.8
CNK CCCT A.06.02	2.4	3.4	3.9	3.8	2.7	2.6	3.6	4.1	4.1	2.9	2.8	3.9	4.4	4.4	3.1	2.9	4.0	4.6	4.6	3.2	3.1	4.3	4.9	4.9	3.5	3.3	4.6	5.2
CNK CCCT A.08.01	2.5	3.6	4.2	4.2	2.9	2.7	3.9	4.5	4.5	3.1	3.0	4.2	4.9	4.8	3.4	3.1	4.4	5.1	5.1	3.5	3.4	4.8	5.5	5.5	3.8	3.7	5.2	5.9
CNK CCCT A.08.02	2.8	4.0	4.6	4.6	3.2	3.0	4.3	5.0	4.9	3.4	3.3	4.6	5.3	5.3	3.7	3.5	4.9	5.6	5.5	3.9	3.7	5.2	6.0	5.9	4.2	4.0	5.6	6.4
CNK CCCT A.10.01	2.8	4.1	4.7	3.5	3.2	3.0	4.4	5.1	5.0	3.4	3.3	4.8	5.5	5.5	3.8	3.5	5.0	5.8	5.7	4.0	3.8	5.4	6.2	6.2	4.3	4.1	5.9	6.7
CNK CCCT A.10.02	3.1	4.5	5.2	5.2	3.6	3.4	4.9	5.6	5.6	3.9	3.7	5.3	6.0	6.0	4.2	3.9	5.5	6.3	6.3	4.4	4.2	6.0	6.8	6.8	4.8	4.6	6.4	7.3
CNK CCCT B.06.01	3.4	4.8	5.5	5.5	3.8	3.6	5.1	5.9	5.9	4.1	3.9	5.5	6.3	6.3	4.4	4.1	5.8	6.6	6.6	4.6	4.4	6.2	7.1	7.0	5.0	4.8	6.6	7.6
CNK CCCT B.06.02	3.7	5.3	6.1	6.0	4.2	4.0	5.7	6.5	6.4	4.5	4.3	6.1	6.9	6.9	4.9	4.5	6.3	7.2	7.2	5.1	4.9	6.8	7.7	7.6	5.4	5.2	7.2	8.2
CNK CCCT B.08.01	3.9	5.6	6.5	6.5	4.4	4.2	6.1	7.0	7.0	4.8	4.6	6.6	7.5	7.5	5.2	4.9	6.9	7.9	7.9	5.5	5.3	7.4	8.5	8.5	5.9	5.7	8.0	9.1
CNK CCCT B.08.02	4.4	6.3	7.2	7.2	5.0	4.8	6.8	7.7	7.7	5.4	5.1	7.3	8.3	8.3	5.8	5.4	7.6	8.7	8.6	6.1	5.8	8.2	9.3	9.3	6.5	6.3	8.7	9.9
CNK CCCT B.10.01	4.3	6.2	7.2	7.2	5.3	4.9	6.7	7.8	7.8	5.3	5.1	7.3	8.4	8.4	5.8	5.4	7.7	8.9	8.8	6.1	5.9	8.4	9.6	9.6	6.6	6.4	9.0	10.4
CNK CCCT B.10.02	4.9	7.0	8.1	8.0	5.5	5.3	7.6	8.7	8.7	6.0	5.7	8.2	9.4	9.3	6.5	6.0	8.6	9.8	9.8	6.8	6.5	9.2	10.6	10.6	7.4	7.1	10.0	11.4
CNK CCCT C.06.01	4.6	6.6	7.6	7.5	5.2	5.0	7.1	8.1	8.1	5.6	5.4	7.6	8.7	8.7	6.1	5.7	8.0	9.1	9.1	6.4	6.1	8.6	9.8	9.7	6.9	6.6	9.2	10.4
CNK CCCT C.06.02	5.2	7.3	8.4	8.3	5.8	5.6	7.8	8.9	8.9	6.3	6.0	8.4	9.5	9.5	6.7	6.3	8.7	10.0	9.9	7.0	6.7	9.3	10.6	10.6	7.5	7.2	9.9	11.3
CNK CCCT C.08.01	5.4	7.7	8.9	8.9	6.1	5.8	8.3	9.6	9.6	6.6	6.3	9.0	10.3	10.3	7.1	6.7	9.5	10.8	10.8	7.5	7.2	10.2	11.7	11.6	8.1	7.8	11.0	12.5
CNK CCCT C.08.02	5.9	8.6	9.9	9.9	6.9	6.5	9.3	10.6	10.6	7.4	7.1	10.0	11.4	11.4	8.0	7.4	10.5	12.0	11.9	8.4	8.0	11.2	12.8	12.7	9.0	8.6	12.0	13.7
CNK CCCT C.10.01	5.8	8.5	9.9	7.3	6.7	6.4	9.2	10.7	10.6	7.3	6.9	10.0	11.5	11.5	7.9	7.3	10.6	12.1	12.1	8.4	8.0	11.4	13.1	13.1	9.1	8.7	12.4	14.1
CNK CCCT C.10.02	6.7	9.6	11.1	11.0	7.6	7.2	10.4	11.9	11.9	8.2	7.8	11.2	12.8	12.8	8.9	8.3	11.8	13.5	13.4	9.4	9.0	12.7	14.5	14.4	10.1	9.7	13.6	15.6
CNK CCCT D.06.01	5.8	8.3	9.5	9.5	6.6	6.3	8.9	10.2	10.2	7.1	6.8	9.6	10.9	10.9	7.6	7.1	10.0	11.5	11.4	8.0	7.7	10.8	12.3	12.2	8.6	8.3	11.5	13.1
CNK CCCT D.06.02	6.5	9.2	10.5	10.5	7.3	7.0	9.8	11.2	11.2	7.9	7.5	10.5	12.0	11.9	8.4	7.9	11.0	12.5	12.5	8.8	8.5	11.8	13.4	13.3	9.5	9.1	12.5	14.2
CNK CCCT D.08.01	6.7	9.7	11.2	11.2	7.7	7.3	10.5	12.0	12.0	8.3	7.9	11.3	13.0	12.9	9.0	8.4	11.9	13.6	13.6	9.5	9.1	12.8	14.7	14.6	10.2	9.8	13.8	15.7
CNK CCCT D.08.02	7.6	10.9	12.5	12.4	8.6	8.2	11.7	13.4	13.3	9.3	8.9	12.6	14.4	14.3	10.0	9.3	13.2	15.0	15.0	10.5	10.1	14.1	16.1	16.0	11.3	10.9	15.1	17.2
CNK CCCT D.10.01	7.3	10.7	12.4	9.1	8.4	8.0	11.6	13.4	13.3	9.1	8.7	12.6	14.5	14.4	9.9	9.2	13.3	15.2	15.2	10.5	10.1	14.3	16.5	16.4	11.4	10.9	15.5	17.8
CNK CCCT D.10.02	8.4	12.1	13.9	13.9	9.5	9.1	13.0	15.0	14.9	10.3	9.8	14.1	16.1	16.1	11.2	10.4	14.8	16.9	16.9	11.8	11.3	15.9	18.2	18.1	12.7	12.2	17.1	19.6
CNK CCCT E.06.01	7.3	10.5	12.0	12.0	8.3	7.9	11.2	12.9	12.8	8.9	8.5	12.1	13.8	13.7	9.6	9.0	12.6	14.4	14.4	10.1	9.7	13.6	15.5	15.4	10.9	10.4	14.5	16.5
CNK CCCT E.06.02	8.2	11.6	13.3	13.2	9.3	8.8	12.4	14.2	14.1	9.9	9.5	13.3	15.2	15.1	10.7	10.0	13.9	15.8	15.7	11.2	10.7	14.8	16.9	16.8	11.9	11.4	15.8	18.0
CNK CCCT E.08.01	8.5	12.2	14.1	14.0	9.6	9.2	13.2	15.1	15.1	10.4	10.0	14.2	16.3	16.2	11.3	10.5	14.9	17.1	17.1	11.9	11.4	16.1	18.4	18.3	12.9	12.3	17.3	19.8
CNK CCCT E.08.02	9.6	13.7	15.7	15.7	10.9	10.4	14.7	16.9	16.8	11.7	11.2	15.8	18.1	18.0	12.6	11.8	16.6	18.9	18.8	13.2	12.7	17.8	20.3	20.2	14.3	13.7	19.0	21.7
CNK CCCT E.10.01	9.2	13.4	15.5	11.5	10.5	10.0	14.5	16.8	16.7	11.4	10.9	15.7	18.1	18.1	12.4	11.6	16.6	19.1	19.0	13.1	12.6	18.0	20.6	20.6	14.3	13.7	19.5	22.3
CNK CCCT E.10.02	10.5	15.2	17.5	17.4	12.0	11.4	16.4	18.8	18.7	13.0	12.4	17.7	20.3	20.2	14.0	13.1	18.6	21.3	21.2	14.8	14.2	20.0	22.9	22.8	16.0	15.3	21.5	24.6
CNK CCCT H.06.01	9.1	13.0	14.9	14.8	10.3	9.8	13.9	15.9	15.9	11.1	10.6	14.9	17.1	17.0	11.9	11.1	15.7	17.9	17.8	12.5	12.0	16.8	19.2	19.1	13.5	12.9	18.0	20.5
CNK CCCT H.06.02	10.2	14.4	16.5	16.4	11.5	10.9	15.4	17.6	17.5	12.3	11.8	16.4	18.8	18.7	13.2	12.3	17.2	19.6	19.6	12.1	11.8	13.2	15.8	15.7	14.8	14.2	19.6	22.2
CNK CCCT H.08.01	10.5	15.2	17.5	17.4	12.0	11.4	16.4	18.8	18.7	13.0	12.4	17.7	20.3	20.2	14.0	13.1	18.6	21.3	21.2	14.8	14.2	20.0	22.9	22.8	16.0	15.3	21.5	24.6
CNK CCCT H.08.02	11.9	17.0	19.5	19.4	13.5	12.8	18.2	20.9	20.8	14.5	13.9	19.6	22.4	22.3	15.6	14.6	20.6	23.5	23.4	16.4	15.7	22.0	25.1	25.0	17.7	17.0	23.6	26.9
CNK CCCT H.10.01	11.4	16.7	19.3	14.3	13.1	12.5	18.1	20.9	20.8	14.2	13.6	19.6	22.6	22.5	15.5	14.4	20.7	23.8	23.7	16.4	15.7	22.4	25.7	25.6	17.8	17.1	24.2	27.7
CNK CCCT H.10.02	13.1	18.9	21.7	21.6	14.9	14.2	20.3	23.4	23.3	16.1	15.4	21.9	25.2	25.1	17.4	16.2	23.1	26.4	26.3	18.4	17.6	24.9	28.4	28.3	19.9	19.1	26.8	30.6
CNK CCCT 2 x H.06.01	18.2	25.9	29.8	29.6	20.6	19.6	27.8	31.9	31.7	22.2	21.2	29.9	34.2	34.0	23.9	22.3	31.3	35.8	35.6	25.1	24.0	33.6	38.3	38.1	27.0	25.9	36.0	41.0
CNK CCCT 2 x H.06.02	20.4	28.8	32.9	32.7	23.0	21.9	30.8	35.1	35.0	24.6	23.5	32.9	37.5	37.3	26.4	24.6	34.4	39.2	39.2	24.2	22.6	36.7	41.8	41.5	29.5	28.3	39.1	44.5
CNK CCCT 2 x H.08.01	21.0	30.4	35.0	34.8	23.9	22.8	32.7	37.6	37.5	25.9	24.7	35.3	40.5	40.3	28.0	26.1	37.1	42.5	42.4	29.6	28.3	40.0	45.8	45.6	32.0	30.7	43.1	49.2
CNK CCCT 2 x H.08.02	23.8	34.0	39.0	38.8	27.0	25.7	36.5	41.8	41.6	29.0	27.7	39.2	44.8	44.6	31.3	29.2	41.1	47.0	46.7	32.9	31.5	44.1	50.3	50.0	35.3	33.9	47.2	53.8
CNK CCCT 2 x H.10.01	22.9	33.4	38.6	38.6	26.2	24.9	36.2	41.7	41.6	28.5	27.2	39.2	45.1	45.0	31.0	28.8	41.4	47.6	47.4	32.7	31.4	44.8	51.4	51.2	35.6	34.2	48.4	55.5
CNK CCCT 2 x H.10.02	26.1	37.7	43.4	43.3	29.7	28.3	40.7	46.8	46.6	32.2	30.7	43.9	50.4	50.2	34.8	32.5	46.2	52.9	52.7	36.7	35.2	49.7	56.9	56				

Cenk LEON CCCT Range (R0)																														
Condition Reference #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28		
Wet Bulb °C	10	10	10	10	10	13	13	13	13	13	16	16	16	16	16	18	18	18	18	18	21	21	21	21	21	24	24	24		
Range °C	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6		
Approach °C	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7		
Inlet Process Temperature °C	20	22	23	25	24	23	25	26	28	27	26	28	29	31	30	28	30	31	33	32	31	33	34	36	35	34	36	37		
Outlet Process Temperature °C	14	16	17	18	16	17	19	20	21	19	20	22	23	24	22	22	24	25	26	24	25	27	28	29	27	28	30	31		
Process Fluid Type	WATER																													
CNK CCCT 2 x J.08.01	29.1	42.0	48.4	48.2	33.1	31.5	45.3	52.0	51.9	35.8	34.2	48.9	56.0	55.8	38.8	36.2	51.4	58.9	58.6	40.9	39.2	55.4	63.3	63.0	44.2	42.4	59.6	68.0		
CNK CCCT 2 x J.08.02	33.0	47.2	54.1	53.9	37.4	35.6	50.6	58.0	57.8	40.3	38.5	54.4	62.2	61.9	43.4	40.5	57.0	65.2	64.8	45.6	43.7	61.2	69.8	69.4	49.0	47.1	65.5	74.6		
CNK CCCT 2 x J.10.01	31.5	46.1	53.3	53.4	36.1	34.4	49.9	57.6	57.4	39.2	37.5	54.1	62.3	62.1	42.7	39.7	57.1	65.6	65.4	45.1	43.3	61.8	70.9	70.6	49.1	47.1	66.8	76.5		
CNK CCCT 2 x J.10.02	36.1	52.2	60.1	59.9	41.1	39.2	56.3	64.7	64.4	44.5	42.5	60.7	69.6	69.4	48.2	44.9	63.8	73.2	72.9	50.8	48.7	68.8	78.7	78.3	54.9	52.7	74.0	84.5		
CNK CCCT K.06.01	14.0	19.9	22.9	22.8	15.8	15.1	21.4	24.5	24.4	17.0	16.3	23.0	26.3	26.2	18.4	17.1	24.1	27.5	27.4	19.3	18.5	25.8	29.5	29.3	20.7	19.9	27.7	31.5		
CNK CCCT K.06.02	15.7	22.2	25.4	25.3	17.7	16.9	23.7	27.1	27.0	19.0	18.1	25.4	28.9	28.8	20.3	19.0	26.5	30.2	30.2	18.6	21.3	20.4	28.3	32.2	32.0	22.8	21.8	30.2	34.3	
CNK CCCT K.08.01	16.1	23.2	26.7	26.7	18.3	17.5	25.1	28.8	28.7	19.8	18.9	27.0	31.0	30.9	21.5	20.0	28.4	32.6	32.4	22.6	21.7	30.6	35.0	34.9	24.5	23.5	33.0	37.6		
CNK CCCT K.08.02	18.3	26.1	30.0	29.8	20.7	19.7	28.0	32.1	32.0	22.3	21.3	30.1	34.4	34.3	24.0	22.4	31.6	36.1	35.9	25.2	24.2	33.9	38.6	38.4	27.2	26.0	36.3	41.3		
CNK CCCT K.10.01	17.4	25.5	29.4	21.8	20.0	19.0	27.6	31.8	31.7	21.7	20.7	29.9	34.4	34.3	23.6	21.9	31.5	36.2	36.1	25.0	23.9	34.1	39.2	39.0	27.1	26.0	36.9	42.3		
CNK CCCT K.10.02	20.0	28.9	33.2	33.1	22.8	21.7	31.1	35.8	35.6	24.6	23.5	33.6	38.5	38.4	26.7	24.8	35.3	40.5	40.3	28.1	26.9	38.1	43.5	43.3	30.4	29.2	41.0	46.8		
CNK CCCT 2 x K.06.01	28.0	39.9	45.7	45.6	31.7	30.2	42.8	49.0	48.8	34.1	32.6	46.0	52.6	52.3	36.7	34.3	48.2	55.0	54.7	38.5	36.9	51.7	58.9	58.6	41.4	39.8	55.3	63.0		
CNK CCCT 2 x K.06.02	31.4	44.4	50.8	50.5	35.4	33.8	47.5	54.2	53.9	38.0	36.3	50.8	57.9	57.6	40.7	38.0	53.0	60.4	60.3	42.6	40.8	56.6	64.4	64.0	45.6	43.7	60.4	68.6		
CNK CCCT 2 x K.08.01	32.2	46.5	53.5	53.3	36.6	34.9	50.1	57.6	57.4	39.6	37.9	54.0	62.0	61.8	42.9	40.0	56.8	65.1	64.9	45.2	43.4	61.3	70.1	69.7	48.9	47.0	65.9	75.3		
CNK CCCT 2 x K.08.02	36.6	52.2	59.9	59.7	41.4	39.5	56.1	64.2	64.0	44.6	42.6	60.2	68.9	68.6	48.0	44.8	63.1	72.1	71.8	50.5	48.4	67.7	77.3	76.8	54.3	52.1	72.6	82.6		
CNK CCCT 2 x K.10.01	34.9	51.0	58.9	43.5	39.9	38.0	55.2	63.6	63.5	43.4	41.4	59.8	68.8	68.6	47.2	43.9	63.1	72.5	72.3	49.9	47.8	68.3	78.3	78.0	54.2	52.1	73.8	84.5		
CNK CCCT 2 x K.10.02	40.0	57.7	66.5	66.2	45.5	43.3	62.3	71.6	71.3	49.2	47.0	67.2	77.0	76.7	53.3	49.7	70.6	80.9	80.6	56.2	53.9	76.1	87.1	86.7	60.8	58.3	81.9	93.5		
CNK CCCT L.06.01	15.3	21.8	25.0	24.9	17.3	16.5	23.4	26.8	26.7	18.6	17.8	25.1	28.7	28.6	20.1	18.7	26.3	30.1	29.9	21.1	20.2	28.2	32.2	32.0	22.6	21.7	30.2	34.4		
CNK CCCT L.06.02	17.2	24.3	27.8	27.6	19.4	18.5	26.0	29.7	29.5	20.8	19.8	27.8	31.7	31.5	22.3	20.8	29.0	33.1	32.9	23.3	22.3	31.0	35.2	35.0	24.9	23.9	33.0	37.5		
CNK CCCT L.08.01	17.6	25.4	29.2	29.1	20.0	19.1	27.4	31.4	31.3	21.7	20.7	29.5	33.9	33.7	23.4	21.8	31.0	35.6	35.4	24.7	23.7	33.5	38.3	38.1	26.7	25.6	36.0	41.1		
CNK CCCT L.08.02	20.0	28.5	32.7	32.6	22.6	21.6	30.6	35.1	35.0	24.4	23.3	32.9	37.6	37.5	26.3	24.5	34.5	39.4	39.2	27.6	26.4	37.0	42.2	42.0	29.7	28.5	39.7	45.2		
CNK CCCT L.10.01	19.0	27.8	32.1	32.8	21.8	20.7	30.1	34.7	34.6	23.7	22.6	32.6	37.6	37.4	25.8	24.0	34.4	39.6	39.4	27.2	26.1	37.3	42.8	42.6	29.6	28.4	40.3	46.1		
CNK CCCT L.10.02	21.8	31.5	36.3	36.2	24.9	23.7	34.0	39.1	38.9	26.9	25.7	36.7	42.1	41.9	29.1	27.1	38.6	44.2	44.0	30.7	29.4	41.6	47.5	47.3	33.2	31.9	44.7	51.1		
CNK CCCT 2 x L.06.01	30.6	43.6	50.0	49.8	34.6	33.0	46.8	53.6	53.4	37.3	35.6	50.2	57.5	57.2	40.1	37.5	52.7	60.2	59.8	42.1	40.4	56.5	64.4	64.0	45.3	43.5	60.5	68.8		
CNK CCCT 2 x L.06.02	34.4	48.6	55.5	55.3	38.7	36.9	51.9	59.3	59.0	41.5	39.7	55.5	63.3	63.0	44.5	41.6	58.0	66.1	65.8	46.6	44.6	62.0	70.5	70.0	49.9	47.8	66.0	75.0		
CNK CCCT 2 x L.08.01	35.2	50.8	58.4	58.2	40.0	38.1	54.7	62.9	62.7	43.3	41.4	59.0	67.7	67.5	46.9	43.7	62.1	71.1	70.8	49.4	47.4	66.9	76.5	76.2	53.4	51.3	72.0	82.2		
CNK CCCT 2 x L.08.02	40.0	57.1	65.5	65.2	45.3	43.1	61.3	70.2	69.9	48.8	46.6	65.8	75.3	74.9	52.5	49.0	69.0	78.9	78.5	55.2	52.9	74.0	84.5	84.0	59.4	56.9	79.3	90.3		
CNK CCCT 2 x L.10.01	38.1	55.6	64.3	64.3	47.5	43.6	61.5	70.2	69.5	47.4	45.2	65.3	75.1	74.9	51.5	47.9	68.8	79.1	78.9	54.5	52.2	74.5	85.5	85.2	59.2	56.9	80.6	92.3		
CNK CCCT 2 x L.10.02	43.7	63.1	72.6	72.4	49.7	47.3	68.0	78.2	77.9	53.8	51.4	73.4	84.2	83.8	58.2	54.3	77.1	88.4	88.0	61.4	58.8	83.1	95.1	94.7	66.4	63.7	89.5	102.2		
CNK CCCT M.06.01	14.6	20.9	23.9	23.8	16.6	15.8	22.4	25.7	25.6	17.8	17.1	24.1	27.5	27.4	19.2	17.9	25.2	28.8	28.7	20.2	19.3	27.0	30.8	30.7	21.7	20.8	29.0	33.0		
CNK CCCT M.06.02	16.4	23.2	26.5	26.4	18.5	17.6	24.8	28.3	28.2	19.8	19.0	26.5	30.3	30.1	21.3	19.9	27.7	31.6	31.5	19.5	19.5	22.3	21.3	29.6	33.7	33.5	23.8	27.8	31.6	35.9
CNK CCCT M.08.01	16.9	24.4	28.1	28.0	19.2	18.3	26.3	30.2	30.1	20.8	19.9	28.3	32.5	32.4	22.5	21.0	29.8	34.2	34.0	23.7	22.7	32.1	36.7	36.6	25.7	24.6	34.6	39.5		
CNK CCCT M.08.02	19.1	27.3	31.4	31.2	21.7	20.7	29.4	33.6	33.5	23.4	22.3	31.5	36.1	35.9	25.2	23.5	33.1	37.8	37.6	26.4	25.3	35.5	40.5	40.2	28.4	27.3	38.0	43.3		
CNK CCCT M.10.01	18.3	26.8	30.9	30.9	21.0	20.0	29.0	33.4	33.3	22.8	21.8	31.4	36.2	36.0	24.8	23.1	33.1	38.1	38.0	26.2	25.1	35.9	41.2	41.0	28.5	27.4	38.8	44.4		
CNK CCCT M.10.02	21.0	30.3	34.9	34.8	23.9	22.7	32.7	37.5	37.4	25.8	24.7	35.2	40.4	40.3	28.0	26.1	37.0	42.5	42.3	29.5	28.3	39.9	45.7	45.5	31.9	30.6	43.0	49.1		
CNK CCCT 2 x M.06.01	29.3	41.8	47.9	47.7	33.2	31.6	44.8	51.3	51.1	35.7	34.1	48.1	55.0	54.8	38.4	35.9	50.4	57.6	57.3	40.4	38.7	54.1	61.7	61.3	43.4	41.6	57.9	65.9		
CNK CCCT 2 x M.06.02	32.9	46.4	53.1	52.8	37.0	35.3	49.6	56.7	56.4	39.7	37.9	53.1	60.5	60.2	42.5	39.8	55.5	63.2	63.0	44.5	42.6	59.2	67.4	66.9	47.6	45.7	63.1	71.7		
CNK CCCT 2 x M.08.01	33.8	48.8	56.1	55.9	38.4	36.6	52.6	60.4	60.2	41.6	39.7	56.7	65.0	64.8	45.0	42.0	59.6	68.3	68.0	47.5	45.5	64.3	73.5	73.1	51.3	49.3	69.2	78.9		
CNK CCCT 2 x M.08.02	38.3	54.7	62.7	62.5	43.4	41.3	58.7	67.3	67.0	46.7	44.6	63.1	72.1	71.8	50.3	47.0	66.1	75.6	75.2	52.9	50.7	71.0	80.9	80.5	56.9	54.6	76.0	86.6		
CNK CCCT 2 x M.10.01	36.6	53.6	61.9	61.8	45.8	43.9	59.9	68.0	67.9	45.6	43.5	62.8	72.3	72.1	49.6	46.1	66.3	76.2	75.9	52.4	50.3	71.8	82.3	82.0	57.0	54.7	77.6	88.8		
CNK CCCT 2 x M.10.02	41.9	60.6	69.7	69.5	47.8	45.5	65.3	75.1	74.8	51.7	49.3	70.5	80.8	80.5	55.9	52.1	74.1	84.9	84.6	59.0	56.5	79.9	91.3	90.9	63.7	61.2	85.9	98.1		
CNK CCCT N.06.01	16.1	23.0	26.4	26.3	18.3	17.4	24.7	28.3																						

Cenk LEON CCCT Range (R0)

Condition Reference #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28
Wet Bulb °C	10	10	10	10	10	13	13	13	13	13	16	16	16	16	16	18	18	18	18	18	21	21	21	21	21	24	24	24
Range °C	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	6	6	
Approach °C	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	4	6	
Inlet Process Temperature °C	20	22	23	25	24	23	25	26	28	27	26	28	29	31	30	28	30	31	33	32	31	33	34	36	35	34	36	
Outlet Process Temperature °C	14	16	17	18	16	17	19	20	21	19	20	22	23	24	22	22	24	25	26	24	25	27	28	29	27	28	30	
Process Fluid Type	WATER																											
CNK CCCT 2 x P.10.02	51.1	73.8	84.9	84.6	58.2	55.4	79.5	91.4	91.1	62.9	60.1	85.8	98.4	98.1	68.1	63.5	90.2	103.4	103.0	71.8	68.8	97.3	111.2	110.7	77.6	74.5	104.7	119.5
CNK CCCT R.06.01	19.5	27.9	32.0	31.8	22.1	21.1	29.9	34.2	34.1	23.8	22.7	32.1	36.7	36.5	25.6	23.9	33.7	38.4	38.2	26.9	25.8	36.1	41.1	40.9	28.9	27.8	38.6	44.0
CNK CCCT R.06.02	22.0	31.0	35.5	35.3	24.7	23.6	33.2	37.9	37.7	26.5	25.3	35.5	40.5	40.2	28.4	26.6	37.1	42.2	26.1	29.8	28.5	39.6	45.0	44.7	31.9	30.5	42.2	47.9
CNK CCCT R.08.01	22.5	32.4	37.3	37.2	25.6	24.4	35.0	40.2	40.0	27.7	26.4	37.7	43.3	43.1	30.0	27.9	39.7	45.4	45.3	31.6	30.3	42.8	48.9	48.7	34.1	32.8	46.0	52.5
CNK CCCT R.08.02	25.5	36.5	41.8	41.7	28.9	27.6	39.2	44.9	44.7	31.1	29.8	42.1	48.1	47.9	33.6	31.3	44.1	50.4	50.1	35.3	33.8	47.3	54.0	53.7	37.9	36.4	50.7	57.7
CNK CCCT R.10.01	24.3	35.6	41.1	41.0	27.8	26.5	38.5	44.4	44.3	30.3	28.9	41.7	48.0	47.8	32.9	30.6	44.0	50.6	50.4	34.8	33.4	47.6	54.6	54.4	37.8	36.3	51.5	59.0
CNK CCCT R.10.02	27.9	40.3	46.4	46.2	31.8	30.2	43.4	49.9	49.8	34.4	32.8	46.9	53.8	53.6	37.2	34.7	49.3	56.5	56.2	39.2	37.6	53.1	60.8	60.5	42.4	40.7	57.2	65.3
CNK CCCT 2 x R.06.01	39.1	55.7	63.9	63.6	44.2	42.2	59.8	68.5	68.2	47.6	45.5	64.2	73.4	73.1	51.3	47.9	67.3	76.9	76.5	53.8	51.6	72.2	82.3	81.8	57.9	55.5	77.3	88.0
CNK CCCT 2 x R.06.02	43.9	62.1	71.0	70.6	49.5	47.2	66.3	75.8	75.4	53.1	50.7	70.9	80.9	80.5	56.9	53.1	74.1	84.5	84.2	59.5	57.0	79.2	90.1	89.5	63.7	61.1	84.4	95.9
CNK CCCT 2 x R.08.01	44.9	64.9	74.7	74.4	51.1	48.7	69.9	80.4	80.1	55.3	52.9	75.4	86.5	86.2	59.9	55.8	79.3	90.9	90.5	63.1	60.5	85.5	97.8	97.3	68.3	65.5	92.0	105.0
CNK CCCT 2 x R.08.02	51.1	72.9	83.7	83.3	57.8	55.1	78.3	89.7	89.3	62.3	59.5	84.1	96.2	95.8	67.1	62.6	88.2	100.8	100.3	70.5	67.6	94.6	107.9	107.3	75.8	72.8	101.4	115.4
CNK CCCT 2 x R.10.01	48.6	71.1	82.1	81.7	55.7	53.0	77.0	88.8	88.5	60.5	57.8	83.4	96.0	95.7	65.8	61.2	88.0	101.1	100.8	69.6	66.7	95.2	109.3	108.9	75.7	72.7	103.0	117.9
CNK CCCT 2 x R.10.02	55.8	80.6	92.8	92.5	63.5	60.5	86.9	99.9	99.5	68.7	65.6	93.7	107.5	107.1	74.4	69.3	98.6	113.0	112.5	78.4	75.2	106.2	121.5	121.0	84.8	81.4	114.3	130.5
CNK CCCT S.06.01	21.6	30.8	35.3	35.2	24.4	23.3	33.0	37.8	37.7	26.3	25.1	35.5	40.6	40.4	28.3	26.4	37.2	42.5	42.2	29.7	28.5	39.9	45.5	45.2	32.0	30.7	42.7	48.6
CNK CCCT S.06.02	24.3	34.3	39.2	39.0	27.3	26.1	36.6	41.9	41.6	29.3	28.0	39.2	44.7	44.4	31.4	29.4	41.0	46.7	46.7	32.9	31.5	43.7	49.7	49.4	35.2	33.7	46.6	53.0
CNK CCCT S.08.01	24.8	35.8	41.3	41.1	28.3	26.9	38.6	44.4	44.2	30.6	29.2	41.7	47.8	47.6	33.1	30.8	43.8	50.2	50.0	34.9	33.4	47.2	54.0	53.8	37.7	36.2	50.8	58.0
CNK CCCT S.08.02	28.2	40.3	46.2	46.0	31.9	30.4	43.3	49.6	49.3	34.4	32.9	46.5	53.1	52.9	37.1	34.6	48.7	55.7	55.4	38.9	37.3	52.3	59.6	59.3	41.9	40.2	56.0	63.8
CNK CCCT S.10.01	26.9	39.3	45.4	45.1	33.6	32.3	42.5	49.1	48.9	33.4	31.9	46.1	53.0	52.9	36.4	33.8	48.6	55.9	55.7	38.5	36.9	52.6	60.4	60.2	41.8	40.2	56.9	65.2
CNK CCCT S.10.02	30.8	44.5	51.3	51.1	35.1	33.4	48.0	55.2	55.0	38.0	36.3	51.8	59.4	59.2	41.1	38.3	54.5	62.4	62.1	43.3	41.5	58.7	67.1	66.8	46.8	45.0	63.2	72.1
CNK CCCT 2 x S.06.01	43.2	61.6	70.6	70.3	48.9	46.6	66.1	75.7	75.3	52.6	50.3	70.9	81.1	80.7	56.6	52.9	74.4	84.9	84.5	59.5	57.0	79.7	90.9	90.4	64.0	61.4	85.4	97.2
CNK CCCT 2 x S.06.02	48.5	68.6	78.4	78.0	54.7	52.1	73.3	83.7	83.3	58.6	56.0	78.4	89.4	88.9	62.8	58.7	81.9	93.3	93.0	65.8	63.0	87.4	99.5	98.9	70.4	67.4	93.2	105.9
CNK CCCT 2 x S.08.01	49.6	71.7	82.5	82.2	56.5	53.8	77.3	88.8	88.5	61.2	58.4	83.4	95.6	95.3	66.2	61.7	87.7	100.4	100.0	69.8	66.9	94.5	108.0	107.5	75.4	72.4	101.7	116.1
CNK CCCT 2 x S.08.02	56.4	80.6	92.4	92.1	63.9	60.9	86.5	99.1	98.7	68.8	65.8	92.9	106.3	105.8	74.1	69.2	97.4	111.3	110.8	77.9	74.6	104.5	119.2	118.6	83.8	80.4	112.0	127.5
CNK CCCT 2 x S.10.01	53.7	78.6	90.8	90.7	61.5	58.5	85.1	98.1	97.8	66.9	63.8	92.2	106.1	105.8	72.7	67.6	97.2	111.7	111.4	76.9	73.8	105.3	120.7	120.3	83.6	80.3	113.8	130.3
CNK CCCT 2 x S.10.02	61.6	89.1	102.5	102.2	70.2	66.8	96.0	110.3	110.0	76.0	72.5	103.6	118.8	118.4	82.2	76.6	108.9	124.8	124.3	86.7	83.1	117.4	134.3	133.6	93.7	90.0	126.3	144.2
CNK CCCT T.06.01	23.6	33.6	38.6	38.4	26.7	25.5	36.1	41.4	41.2	28.8	27.5	38.8	44.3	44.1	31.0	28.9	40.6	46.4	46.2	32.5	31.2	43.6	49.7	49.4	35.0	33.5	46.7	53.1
CNK CCCT T.06.02	26.5	37.5	42.9	42.7	29.9	28.5	40.1	45.8	45.5	32.1	30.6	42.9	48.9	48.6	34.4	32.1	44.8	51.0	51.0	31.5	30.0	34.4	47.8	47.8	34.4	32.9	46.7	53.1
CNK CCCT T.08.01	27.1	39.2	45.1	44.9	30.9	29.4	42.2	48.5	48.3	33.4	31.9	45.5	52.2	52.0	36.2	33.7	47.9	54.9	54.6	38.1	36.5	51.6	59.0	58.7	41.2	39.6	55.5	63.4
CNK CCCT T.08.02	30.8	44.0	50.5	50.3	34.9	33.3	47.3	54.2	53.9	37.6	35.9	50.8	58.1	57.8	40.5	37.8	53.3	60.8	60.5	42.6	40.8	57.1	65.2	64.8	45.8	43.9	61.2	69.7
CNK CCCT T.10.01	29.3	42.9	49.6	49.6	36.6	33.6	46.4	53.5	53.4	36.5	34.8	50.3	57.9	57.7	39.7	36.9	53.1	61.0	60.8	42.0	40.3	57.5	65.9	65.7	45.6	43.8	62.1	71.1
CNK CCCT T.10.02	33.7	48.6	56.0	55.8	38.3	36.5	52.4	60.3	60.1	41.5	39.6	56.6	64.9	64.6	44.9	41.8	59.5	68.2	67.9	47.3	45.4	64.1	73.3	73.0	51.2	49.1	69.0	78.8
CNK CCCT 2 x T.06.01	47.2	67.3	77.2	76.9	53.4	50.9	72.2	82.7	82.4	57.5	55.0	77.6	88.7	88.2	61.9	57.8	81.3	92.8	92.4	65.0	62.3	87.2	99.4	98.8	69.9	67.1	93.3	106.2
CNK CCCT 2 x T.06.02	53.1	75.0	85.8	85.3	59.8	57.0	80.2	91.6	91.1	64.1	61.2	85.7	97.8	97.2	68.7	64.2	89.6	102.1	102.1	63.0	61.9	71.9	88.9	88.7	59.7	57.8	73.8	82.0
CNK CCCT 2 x T.08.01	54.2	78.3	90.1	89.8	61.7	58.8	84.4	97.0	96.7	66.8	63.8	91.1	104.5	104.1	72.3	67.4	95.8	109.7	109.3	76.2	73.1	103.2	118.0	117.5	82.4	79.1	111.1	126.8
CNK CCCT 2 x T.08.02	61.7	88.1	101.0	100.6	69.8	66.5	94.6	108.3	107.9	75.2	71.9	101.6	116.2	115.6	81.0	75.6	106.5	121.7	121.1	85.1	81.6	114.3	130.3	129.6	91.6	87.9	122.4	139.4
CNK CCCT 2 x T.10.01	58.7	85.8	99.1	98.9	67.2	63.9	92.9	107.1	106.8	73.0	69.7	100.6	115.8	115.4	79.4	73.8	106.1	122.0	121.6	84.0	80.5	114.9	131.8	131.3	91.3	87.7	124.2	142.2
CNK CCCT 2 x T.10.02	67.3	97.3	112.0	111.6	76.7	73.0	104.9	120.5	120.1	83.0	79.2	113.1	129.8	129.3	89.8	83.7	119.0	136.3	135.8	94.7	90.7	128.2	146.7	146.0	102.3	98.3	138.0	157.5
CNK CCCT U.06.01	25.6	36.6	41.9	41.8	29.0	27.7	39.3	45.0	44.8	31.3	29.9	42.2	48.2	48.0	33.7	31.4	44.2	50.5	50.2	35.3	33.9	47.4	54.0	53.7	38.0	36.5	50.7	57.7
CNK CCCT U.06.02	28.9	40.8	46.6	46.4	32.5	31.0	43.6	49.8	49.5	34.9	33.3	46.6	53.2	52.9	37.4	34.9	48.7	55.5	55.2	39.1	37.5	52.0	59.2	58.8	41.9	40.1	55.5	63.0
CNK CCCT U.08.01	29.5	42.5	49.0	48.8	33.5	31.9	45.9	52.7	52.5	36.3	34.7	49.5																

Cenk LEON CCCT Range (R0)

Condition Reference #	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49
Wet Bulb °C	24	24	27	27	27	27	27	29	29	29	29	29	32.2	32.2	32.2	32.2	32.2	21	25.56	27	28
Range °C	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	5	6.67	5	5
Approach °C	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	6	6.67	5	4
Inlet Process Temperature °C	39	38	37	39	40	42	41	39	41	42	44	43	42.2	44.2	45.2	46.2	46.2	32	38.90	37	37
Outlet Process Temperature °C	32	30	31	33	34	35	33	33	35	36	37	35	36.2	38.2	39.2	40.2	38.2	27	32.23	32	32
Process Fluid Type																					
CNK CCCT A.06.01	4.8	3.4	3.3	4.5	5.2	5.1	3.7	3.4	4.7	5.4	5.3	3.8	3.7	5.1	5.7	5.7	4.1	4.6	4.4	4.5	3.8
CNK CCCT A.06.02	5.2	3.7	3.5	4.9	5.5	5.5	3.9	3.7	5.1	5.7	5.7	4.1	3.9	5.4	6.1	6.1	4.4	5.0	4.8	4.8	4.1
CNK CCCT A.08.01	5.9	4.1	4.0	5.5	6.3	6.3	4.4	4.2	5.8	6.6	6.6	4.7	4.5	6.2	7.1	7.0	5.0	5.5	5.4	5.5	4.7
CNK CCCT A.08.02	6.3	4.5	4.3	6.0	6.8	6.8	4.8	4.5	6.2	7.1	7.0	5.0	4.9	6.7	7.6	7.5	5.4	6.0	5.8	5.9	5.1
CNK CCCT A.10.01	6.7	4.7	4.5	6.3	7.2	7.2	5.1	4.7	6.7	7.6	7.6	5.3	5.2	7.2	8.2	8.1	5.8	6.3	6.2	6.3	5.3
CNK CCCT A.10.02	7.3	5.1	4.9	6.9	7.9	7.8	5.5	5.2	7.2	8.2	8.2	5.8	5.6	7.8	8.8	8.8	6.3	6.9	6.7	6.8	5.8
CNK CCCT B.06.01	7.5	5.3	5.1	7.1	8.1	8.0	5.7	5.4	7.4	8.4	8.4	6.0	5.8	7.9	9.0	8.9	6.4	7.2	6.9	7.0	6.0
CNK CCCT B.06.02	8.1	5.8	5.6	7.7	8.7	8.6	6.2	5.8	8.0	9.0	9.0	6.4	6.2	8.5	9.6	9.5	6.9	7.8	7.5	7.6	6.5
CNK CCCT B.08.01	9.1	6.4	6.2	8.6	9.8	9.7	6.9	6.5	9.0	10.2	10.2	7.2	7.0	9.7	11.0	10.9	7.8	8.6	8.4	8.5	7.3
CNK CCCT B.08.02	9.9	7.0	6.7	9.3	10.6	10.5	7.5	7.1	9.8	11.1	11.0	7.9	7.6	10.4	11.8	11.7	8.4	9.4	9.1	9.2	7.9
CNK CCCT B.10.01	10.3	7.2	6.9	9.8	11.2	11.1	7.8	7.3	10.3	11.7	11.6	8.2	8.0	11.1	12.6	12.5	8.9	9.7	9.5	9.6	8.2
CNK CCCT B.10.02	11.3	8.0	7.7	10.7	12.2	12.1	8.6	8.0	11.2	12.7	12.7	9.0	8.7	12.0	13.7	13.6	9.7	10.7	10.4	10.6	9.0
CNK CCCT C.06.01	10.4	7.4	7.1	9.8	11.1	11.0	7.9	7.4	10.2	11.6	11.5	8.2	7.9	10.9	12.4	12.3	8.8	9.9	9.5	9.7	8.3
CNK CCCT C.06.02	11.2	8.0	7.7	10.6	12.0	11.9	8.5	8.0	11.0	12.5	12.4	8.9	8.6	11.7	13.3	13.1	9.5	10.8	10.3	10.5	9.0
CNK CCCT C.08.01	12.5	8.8	8.4	11.8	13.4	13.4	9.5	8.9	12.3	14.1	14.0	9.9	9.6	13.3	15.1	15.0	10.7	11.8	11.5	11.7	9.9
CNK CCCT C.08.02	13.6	9.7	9.3	12.9	14.6	14.5	10.4	9.7	13.4	15.2	15.1	10.8	10.4	14.3	16.3	16.1	11.6	13.0	12.5	12.7	10.9
CNK CCCT C.10.01	14.1	9.9	9.5	13.3	15.2	15.2	10.7	10.0	14.0	16.0	15.9	11.2	10.9	15.1	17.2	17.1	12.2	13.2	13.0	13.2	11.2
CNK CCCT C.10.02	15.5	10.9	10.5	14.7	16.7	16.6	11.8	11.0	15.4	17.5	17.4	12.3	11.9	16.5	18.7	18.6	13.3	14.7	14.3	14.5	12.4
CNK CCCT D.06.01	13.0	9.3	8.9	12.3	14.0	13.9	9.9	9.3	12.8	14.6	14.5	10.4	10.0	13.7	15.6	15.4	11.1	12.4	12.0	12.2	10.4
CNK CCCT D.06.02	14.1	10.1	9.7	13.3	15.1	15.0	10.8	10.1	13.9	15.7	15.6	11.2	10.8	14.7	16.7	16.5	11.9	13.5	13.0	13.2	11.3
CNK CCCT D.08.01	15.7	11.0	10.6	14.8	16.9	16.8	11.9	11.2	15.5	17.7	17.6	12.5	12.1	16.7	18.9	18.8	13.4	14.8	14.4	14.7	12.5
CNK CCCT D.08.02	17.1	12.2	11.7	16.2	18.4	18.3	13.0	12.2	16.9	19.2	19.0	13.6	13.1	18.0	20.5	20.3	14.6	16.3	15.8	16.0	13.7
CNK CCCT D.10.01	17.7	12.4	11.9	16.7	19.1	19.0	13.4	12.6	17.6	20.1	20.0	14.1	13.6	19.0	21.6	21.5	15.3	16.6	16.3	16.5	14.1
CNK CCCT D.10.02	19.5	13.7	13.2	18.4	21.0	20.9	14.8	13.9	19.3	22.0	21.8	15.5	15.0	20.7	23.6	23.4	16.7	18.4	17.9	18.2	15.5
CNK CCCT E.06.01	16.4	11.7	11.2	15.5	17.6	17.5	12.5	11.7	16.2	18.4	18.2	13.1	12.6	17.3	19.6	19.4	14.0	15.6	15.1	15.4	13.1
CNK CCCT E.06.02	17.8	12.7	12.2	16.8	19.1	18.9	13.6	12.8	17.5	19.8	19.7	14.2	13.6	18.6	21.1	20.9	15.1	17.1	16.4	16.7	14.3
CNK CCCT E.08.01	19.7	13.9	13.3	18.6	21.2	21.1	14.9	14.0	19.5	22.2	22.1	15.7	15.2	20.9	23.8	23.6	16.9	18.6	18.1	18.4	15.7
CNK CCCT E.08.02	21.6	15.3	14.7	20.4	23.2	23.0	16.4	15.4	21.3	24.1	24.0	17.1	16.5	22.7	25.8	25.6	18.4	20.5	19.8	20.2	17.2
CNK CCCT E.10.01	22.2	15.5	14.9	21.0	24.0	23.9	16.8	15.7	22.1	25.2	25.0	17.7	17.1	23.8	27.1	27.0	19.1	20.8	20.4	20.7	17.6
CNK CCCT E.10.02	24.5	17.2	16.6	23.1	26.4	26.2	18.6	17.4	24.2	27.6	27.4	19.5	18.8	26.0	29.6	29.4	21.0	23.1	22.5	22.9	19.5
CNK CCCT H.06.01	20.4	14.5	13.9	19.2	21.8	21.7	15.5	14.5	20.1	22.8	22.6	16.2	15.6	21.4	24.3	24.1	17.3	19.4	18.7	19.0	16.3
CNK CCCT H.06.02	22.1	15.8	15.1	20.8	23.6	23.4	16.8	15.8	21.7	24.5	24.4	17.5	16.9	23.0	26.1	25.8	18.6	21.1	20.3	20.6	17.7
CNK CCCT H.08.01	24.5	17.2	16.6	23.1	26.4	26.2	18.6	17.4	24.2	27.6	27.4	19.5	18.8	26.0	29.6	29.4	21.0	23.1	22.5	22.9	19.5
CNK CCCT H.08.02	26.7	19.0	18.2	25.2	28.7	28.5	20.3	19.1	26.4	29.9	29.7	21.3	20.5	28.2	32.0	31.7	22.8	25.4	24.6	25.0	21.4
CNK CCCT H.10.01	27.6	19.3	18.6	26.1	29.9	29.7	20.9	19.6	27.5	31.3	31.2	22.0	21.3	29.7	33.8	33.6	23.8	25.9	25.4	25.8	22.0
CNK CCCT H.10.02	30.4	21.4	20.6	28.8	32.8	32.6	23.1	21.7	30.1	34.3	34.1	24.2	23.4	32.4	36.8	36.5	26.1	28.8	28.0	28.4	24.3
CNK CCCT 2 x H.06.01	40.7	28.9	27.8	38.4	43.7	43.4	31.0	29.1	40.1	45.6	45.2	32.4	31.2	42.9	48.6	48.2	34.7	38.8	37.4	38.1	32.5
CNK CCCT 2 x H.06.02	44.1	31.5	30.2	41.6	47.2	46.9	33.6	31.6	43.3	49.1	48.7	35.0	33.7	46.1	52.1	51.7	37.3	42.3	40.6	41.3	35.3
CNK CCCT 2 x H.08.01	48.9	34.5	33.1	46.3	52.7	52.4	37.1	34.8	48.5	55.2	54.8	39.0	37.7	52.1	59.1	58.7	42.0	46.3	45.0	45.8	39.0
CNK CCCT 2 x H.08.02	53.5	38.0	36.4	50.5	57.4	57.0	40.7	38.2	52.7	59.9	59.5	42.5	41.0	56.4	63.9	63.4	45.5	50.9	49.2	50.0	42.7
CNK CCCT 2 x H.10.01	55.2	38.6	37.1	52.3	59.7	59.4	41.8	39.2	54.9	62.7	62.4	44.0	42.6	59.3	67.6	67.2	47.7	51.9	50.8	51.6	43.9
CNK CCCT 2 x H.10.02	60.8	42.9	41.2	57.5	65.5	65.2	46.2	43.3	60.2	68.6	68.1	48.4	46.8	64.7	73.5	73.0	52.2	57.5	56.0	56.9	48.5
CNK CCCT I.06.01	25.6	18.2	17.5	24.2	27.5	27.3	19.5	18.3	25.3	28.7	28.5	20.4	19.7	27.0	30.6	30.4	21.8	24.4	23.6	24.0	20.5
CNK CCCT I.06.02	27.9	19.9	19.1	26.3	29.8	29.6	21.2	19.9	27.3	31.0	30.7	22.1	21.3	29.1	32.9	32.6	23.5	26.7	25.7	26.0	22.3
CNK CCCT I.08.01	30.7	21.7	20.8	29.1	33.1	32.9	23.3	21.9	30.4	34.7	34.4	24.5	23.7	32.7	37.2	36.9	26.4	29.1	28.3	28.7	24.5
CNK CCCT I.08.02	33.7	23.9	22.9	31.8	36.2	35.9	25.6	24.0	33.2	37.7	37.4	26.8	25.8	35.5	40.2	39.9	28.7	32.0	31.0	31.5	26.9
CNK CCCT I.10.01	34.6	24.2	23.3	32.8	37.4	37.3	26.2	24.6	34.4	39.3	39.1	27.6	26.7	37.2	42.4	42.1	29.9	32.5	31.9	32.4	27.5
CNK CCCT I.10.02	38.2	26.9	25.9	36.1	41.2	40.9	29.0	27.2	37.8	43.1	42.8	30.4	29.4	40.7	46.2	45.9	32.8	36.1	35.2	35.7	30.5
CNK CCCT 2 x I.06.01	51.3	36.4	35.0	48.4	55.0	54.7	39.0	36.6	50.6	57.4	57.0	40.8	39.3	54.0	61.2	60.7	43.7	48.8	47.2	48.0	41.0
CNK CCCT 2 x I.06.02	55.7	39.8	38.2	52.5	59.6	59.2	42.4	39.9	54.7	62.0	61.5	44.2	42.6	58.1	65.8	65.2	47.1	53.4	51.3	52.1	44.6
CNK CCCT 2 x I.08.01	61.5	43.3	41.7	58.1	66.2	65.8	46.7	43.8	60.9	69.3	68.9	49.0	47.3	65.4	74.3	73.8	52.7	58.1	56.5	57.5	49.0
CNK CCCT 2 x I.08.02	67.3	47.8	45.9	63.6	72.3	71.8	51.2	48.1	66.4	75.4	74.9	53.5	51.6	71.0	80.5	79.9	57.3	64.1	62.0	63.0	53.8
CNK CCCT 2 x I.10.01	69.2	48.4	46.6	65.5	74.9	74.5	52.4	49.1	68.9	78.6	78.2	55.2	53.4	74.4	84.7	84.2	59.8	65.1	63.7	64.8	55.1
CNK CCCT 2 x I.10.02	76.4	53.8	51.7	72.2	82.3	81.9	58.0	54.4	75.7	86.1	85.6	60.8									

Cenk LEON CCCT Range (R0)

Condition Reference #	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49
Wet Bulb °C	24	24	27	27	27	27	27	29	29	29	29	29	32.2	32.2	32.2	32.2	32.2	21	25.56	27	28
Range °C	7	8	6	6	6	7	8	6	6	7	8	8	6	6	7	8	8	5	6.67	5	5
Approach °C	8	6	4	6	7	8	6	4	6	7	8	6	6	7	8	8	6	6	6.67	5	4
Inlet Process Temperature °C	39	38	37	39	40	42	41	39	41	42	44	43	42.2	44.2	45.2	46.2	46.2	32	38.90	37	37
Outlet Process Temperature °C	32	30	31	33	34	35	33	33	35	36	37	35	36.2	38.2	39.2	40.2	38.2	27	32.23	32	32
Process Fluid Type																					
CNK CCCT 2 x J.08.01	67.7	47.7	45.9	64.0	72.9	72.5	51.4	48.2	67.0	76.3	75.8	53.9	52.1	72.0	81.8	81.2	58.1	64.0	62.2	63.3	54.0
CNK CCCT 2 x J.08.02	74.2	52.7	50.6	70.1	79.7	79.1	56.4	53.0	73.2	83.1	82.5	59.0	56.9	78.2	88.7	88.0	63.2	70.6	68.3	69.4	59.3
CNK CCCT 2 x J.10.01	76.1	53.2	51.2	72.1	82.4	82.0	57.7	54.0	75.8	86.5	86.0	60.7	58.8	81.8	93.2	92.6	65.8	71.6	70.1	71.2	60.6
CNK CCCT 2 x J.10.02	84.1	59.3	57.0	79.5	90.6	90.1	63.8	59.9	83.3	94.8	94.2	67.0	64.7	89.5	101.7	101.0	72.1	79.5	77.5	78.7	67.1
CNK CCCT K.06.01	31.3	22.2	21.4	29.6	33.6	33.4	23.8	22.4	30.8	35.0	34.8	24.9	24.0	33.0	37.4	37.1	26.6	29.8	28.8	29.3	25.0
CNK CCCT K.06.02	34.1	24.3	23.3	32.1	36.4	36.2	25.9	24.4	33.4	37.9	37.6	27.0	26.0	35.5	40.2	39.9	28.8	32.6	31.4	31.8	27.2
CNK CCCT K.08.01	37.4	26.4	25.4	35.4	40.3	40.1	28.4	26.7	37.1	42.2	41.9	29.8	28.8	39.8	45.3	44.9	32.1	35.4	34.4	35.0	29.9
CNK CCCT K.08.02	41.1	29.2	28.0	38.8	44.1	43.8	31.2	29.3	40.5	46.0	45.7	32.7	31.5	43.3	49.1	48.7	35.0	39.1	37.8	38.4	32.8
CNK CCCT K.10.01	42.1	29.4	28.3	39.8	45.5	45.3	31.9	29.9	41.9	47.8	47.5	33.6	32.5	45.2	51.5	51.2	36.3	39.6	38.7	39.4	33.5
CNK CCCT K.10.02	46.5	32.8	31.5	44.0	50.1	49.8	35.3	33.1	46.1	52.5	52.1	37.0	35.8	49.5	56.3	55.9	39.9	44.0	42.8	43.5	37.1
CNK CCCT 2 x K.06.01	62.6	44.5	42.7	59.1	67.2	66.7	47.6	44.7	61.7	70.0	69.5	49.8	48.0	65.9	74.7	74.1	53.3	59.6	57.5	58.5	50.0
CNK CCCT 2 x K.06.02	68.1	48.7	46.7	64.2	72.9	72.3	51.9	48.7	66.8	75.8	75.1	54.0	52.0	71.1	80.4	79.7	57.5	65.2	62.7	63.7	54.5
CNK CCCT 2 x K.08.01	74.9	52.8	50.7	70.8	80.7	80.2	56.8	53.3	74.2	84.4	83.9	59.6	57.6	79.7	90.5	89.9	64.2	70.8	68.9	70.0	59.7
CNK CCCT 2 x K.08.02	82.1	58.3	56.0	77.6	88.2	87.6	62.5	58.6	81.0	92.0	91.3	65.3	63.0	86.6	98.2	97.4	70.0	78.2	75.6	76.8	65.6
CNK CCCT 2 x K.10.01	84.2	58.9	56.6	79.7	91.1	90.6	63.7	59.7	83.8	95.6	95.1	67.1	64.9	90.5	103.0	102.4	72.7	79.1	77.5	78.7	67.0
CNK CCCT 2 x K.10.02	93.0	65.6	63.0	88.0	100.3	99.7	70.6	66.3	92.2	104.9	104.3	74.1	71.6	99.0	112.5	111.7	79.8	88.0	85.7	87.0	74.2
CNK CCCT L.06.01	34.2	24.3	23.3	32.3	36.7	36.5	26.0	24.4	33.7	38.3	38.0	27.2	26.2	36.0	40.8	40.5	29.1	32.6	31.5	32.0	27.3
CNK CCCT L.06.02	37.3	26.6	25.5	35.1	39.8	39.5	28.4	26.6	36.6	41.4	41.1	29.6	28.4	38.9	44.0	43.6	31.5	35.7	34.3	34.8	29.8
CNK CCCT L.08.01	40.9	28.8	27.7	38.7	44.1	43.8	31.0	29.1	40.5	46.1	45.8	32.6	31.5	43.5	49.4	49.1	35.1	38.7	37.6	38.3	32.6
CNK CCCT L.08.02	44.9	31.9	30.6	42.4	48.2	47.9	34.1	32.1	44.3	50.3	49.9	35.7	34.4	47.3	53.7	53.2	38.2	42.7	41.3	42.0	35.9
CNK CCCT L.10.01	45.9	32.1	30.9	43.5	49.7	49.5	34.8	32.6	45.7	52.2	51.9	36.6	35.4	49.4	56.2	55.9	39.7	43.2	42.3	43.0	36.6
CNK CCCT L.10.02	50.8	35.8	34.4	48.1	54.8	54.4	38.6	36.2	50.3	57.3	56.9	40.5	39.1	54.1	61.5	61.0	43.6	48.1	46.8	47.5	40.5
CNK CCCT 2 x L.06.01	68.4	48.6	46.7	64.6	73.4	72.9	52.1	48.9	67.4	76.6	76.0	54.4	52.5	72.1	81.7	81.0	58.2	65.2	62.9	64.0	54.7
CNK CCCT 2 x L.06.02	74.5	53.2	51.1	70.2	79.7	79.1	56.7	53.3	73.1	82.9	82.2	59.1	56.9	77.7	88.0	87.2	63.0	71.4	68.6	69.6	59.6
CNK CCCT 2 x L.08.01	81.8	57.7	55.4	77.3	88.1	87.6	62.1	58.3	81.0	92.2	91.6	65.1	63.0	87.0	98.9	98.2	70.2	77.3	75.2	76.5	65.3
CNK CCCT 2 x L.08.02	89.8	63.7	61.2	84.8	96.4	95.8	68.3	64.1	88.5	100.6	99.8	71.4	68.9	94.6	107.3	106.5	76.5	85.4	82.7	84.0	71.7
CNK CCCT 2 x L.10.01	91.9	64.3	61.8	87.0	99.4	98.9	69.6	65.2	91.4	104.3	103.8	73.3	70.9	98.7	112.5	111.8	79.3	86.4	84.6	85.9	73.1
CNK CCCT 2 x L.10.02	101.6	71.6	68.8	96.1	109.5	108.9	77.1	72.4	100.7	114.6	113.9	80.9	78.2	108.2	122.9	122.0	87.2	96.1	93.6	95.1	81.1
CNK CCCT M.06.01	32.8	23.3	22.4	30.9	35.2	34.9	24.9	23.4	32.3	36.7	36.4	26.1	25.1	34.5	39.1	38.8	27.9	31.2	30.1	30.6	26.2
CNK CCCT M.06.02	35.6	25.4	24.4	33.6	38.1	37.8	27.1	25.5	34.9	39.6	39.3	28.2	27.2	37.1	42.0	41.7	30.1	34.1	32.8	33.3	28.5
CNK CCCT M.08.01	39.3	27.7	26.6	37.1	42.3	42.1	29.8	28.0	38.9	44.3	44.0	31.3	30.2	41.8	47.5	47.1	33.7	37.1	36.1	36.7	31.3
CNK CCCT M.08.02	43.0	30.5	29.3	40.6	46.2	45.9	32.7	30.7	42.4	48.2	47.8	34.2	33.0	45.3	51.4	51.0	36.6	40.9	39.6	40.2	34.4
CNK CCCT M.10.01	44.2	30.9	29.7	41.9	47.8	47.6	33.5	31.4	44.0	50.2	49.9	35.3	34.1	47.5	54.1	53.8	38.2	41.6	40.7	41.4	35.2
CNK CCCT M.10.02	48.8	34.4	33.1	46.2	52.6	52.3	37.0	34.8	48.3	55.0	54.7	38.9	37.6	51.9	59.0	58.6	41.9	46.2	44.9	45.7	38.9
CNK CCCT 2 x M.06.01	65.5	46.6	44.7	61.9	70.3	69.9	49.9	46.8	64.6	73.3	72.8	52.1	50.3	69.0	78.2	77.6	55.8	62.4	60.2	61.3	52.4
CNK CCCT 2 x M.06.02	71.2	50.9	48.8	67.1	76.2	75.6	54.2	50.9	69.9	79.2	78.6	56.5	54.4	74.3	84.1	83.4	60.2	68.2	65.6	66.5	57.0
CNK CCCT 2 x M.08.01	78.5	55.4	53.2	74.3	84.6	84.1	59.6	56.0	77.8	88.6	88.0	62.6	60.5	83.6	95.0	94.3	67.4	74.3	72.2	73.5	62.7
CNK CCCT 2 x M.08.02	86.0	61.1	58.6	81.3	92.4	91.8	65.4	61.4	84.8	96.4	95.7	68.4	66.0	90.7	102.9	102.0	73.3	81.9	79.2	80.4	68.7
CNK CCCT 2 x M.10.01	88.4	61.9	59.5	83.7	95.7	95.2	67.0	62.8	88.0	100.4	99.9	70.5	68.2	95.1	108.3	107.6	76.4	83.1	81.4	82.7	70.4
CNK CCCT 2 x M.10.02	97.6	68.8	66.1	92.3	105.2	104.6	74.1	69.5	96.7	110.1	109.4	77.7	75.1	103.9	118.1	117.2	83.7	92.3	89.9	91.3	77.9
CNK CCCT N.06.01	36.1	25.7	24.6	34.1	38.8	38.5	27.5	25.8	35.6	40.4	40.1	28.7	27.7	38.0	43.1	42.8	30.7	34.4	33.2	33.8	28.9
CNK CCCT N.06.02	39.3	28.1	26.9	37.0	42.0	41.7	29.9	28.1	38.5	43.7	43.3	31.2	30.0	41.0	46.4	46.0	33.2	37.6	36.1	36.7	31.4
CNK CCCT N.08.01	43.2	30.5	29.3	40.9	46.6	46.3	32.8	30.8	42.8	48.7	48.4	34.4	33.3	46.0	52.3	51.9	37.1	40.9	39.8	40.4	34.5
CNK CCCT N.08.02	47.4	33.6	32.3	44.8	50.9	50.6	36.0	33.8	46.7	53.1	52.7	37.7	36.4	50.0	56.7	56.2	40.4	45.1	43.6	44.3	37.9
CNK CCCT N.10.01	48.6	34.0	32.7	46.1	52.6	52.4	36.8	34.5	48.4	55.2	54.9	38.8	37.5	52.3	59.5	59.2	42.0	45.7	44.8	45.5	38.7
CNK CCCT N.10.02	53.7	37.9	36.4	50.8	57.9	57.6	40.8	38.3	53.2	60.6	60.2	42.8	41.3	57.2	65.0	64.5	46.1	50.8	49.5	50.3	42.9
CNK CCCT 2 x N.06.01	72.2	51.3	49.3	68.2	77.5	77.0	54.9	51.6	71.2	80.8	80.2	57.4	55.4	76.1	86.2	85.5	61.5	68.8	66.4	67.5	57.7

Cenk LEON CCCT Range (R0)

Condition Reference #	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49
Wet Bulb °C	24	24	27	27	27	27	27	29	29	29	29	29	32.2	32.2	32.2	32.2	32.2	21	25.56	27	28
Range °C	7	8	6	6	6	7	8	6	6	6	7	8	6	6	6	7	8	5	6.67	5	5
Approach °C	8	6	4	6	7	8	6	4	6	7	8	6	4	6	7	8	6	6	6.67	5	4
Inlet Process Temperature °C	39	38	37	39	40	42	41	39	41	42	44	43	42.2	44.2	45.2	46.2	46.2	32	38.90	37	37
Outlet Process Temperature °C	32	30	31	33	34	35	33	33	35	36	37	35	36.2	38.2	39.2	40.2	38.2	27	32.23	32	32
Process Fluid Type																					
CNK CCCT 2 x P.10.02	118.9	83.8	80.5	112.4	128.1	127.4	90.2	84.7	117.8	134.1	133.2	94.7	91.5	126.5	143.8	142.8	102.0	112.4	109.5	111.2	94.8
CNK CCCT R.06.01	43.7	31.1	29.8	41.3	46.9	46.6	33.3	31.2	43.1	48.9	48.6	34.8	33.5	46.0	52.2	51.8	37.2	41.6	40.2	40.9	34.9
CNK CCCT R.06.02	47.6	34.0	32.6	44.9	50.9	50.5	36.2	34.0	46.7	52.9	52.5	37.8	36.3	49.7	56.2	55.7	40.2	45.6	43.8	44.5	38.1
CNK CCCT R.08.01	52.2	36.8	35.4	49.4	56.3	56.0	39.7	37.2	51.8	58.9	58.5	41.6	40.2	55.6	63.2	62.7	44.8	49.4	48.1	48.9	41.7
CNK CCCT R.08.02	57.4	40.7	39.1	54.2	61.6	61.2	43.6	41.0	56.6	64.3	63.8	45.6	44.0	60.5	68.6	68.0	48.9	54.6	52.8	53.6	45.8
CNK CCCT R.10.01	58.7	41.0	39.5	55.6	63.5	63.2	44.4	41.7	58.4	66.6	66.3	46.8	45.3	63.1	71.8	71.4	50.7	55.2	54.0	54.9	46.7
CNK CCCT R.10.02	64.9	45.8	44.0	61.4	70.0	69.6	49.3	46.2	64.3	73.2	72.8	51.7	50.0	69.1	78.5	78.0	55.7	61.4	59.8	60.7	51.8
CNK CCCT 2 x R.06.01	87.4	62.1	59.6	82.6	93.8	93.2	66.5	62.5	86.2	97.9	97.1	69.5	67.1	92.1	104.4	103.5	74.4	83.3	80.4	81.8	69.9
CNK CCCT 2 x R.06.02	95.2	68.0	65.2	89.8	101.8	101.1	72.5	68.1	93.4	105.9	105.0	75.5	72.7	99.3	112.4	111.5	80.4	91.2	87.6	89.0	76.2
CNK CCCT 2 x R.08.01	104.5	73.7	70.8	98.8	112.6	112.0	79.3	74.5	103.5	117.8	117.1	83.2	80.4	111.2	126.4	125.5	89.6	98.8	96.1	97.8	83.4
CNK CCCT 2 x R.08.02	114.7	81.4	78.2	108.4	123.2	122.4	87.3	81.9	113.1	128.5	127.6	91.2	88.0	120.9	137.2	136.1	97.7	109.2	105.6	107.3	91.7
CNK CCCT 2 x R.10.01	117.4	82.1	79.0	111.2	127.0	126.4	88.9	83.3	116.8	133.3	132.6	93.6	90.6	126.2	143.7	142.8	101.4	110.3	108.1	109.8	93.4
CNK CCCT 2 x R.10.02	129.9	91.5	88.0	122.8	140.0	139.1	98.6	92.5	128.6	146.4	145.5	103.4	99.9	138.2	157.0	155.9	111.4	122.8	119.6	121.5	103.6
CNK CCCT S.06.01	48.3	34.3	33.0	45.6	51.8	51.5	36.7	34.5	47.6	54.1	53.7	38.4	37.0	50.9	57.7	57.2	41.1	46.0	44.4	45.2	38.6
CNK CCCT S.06.02	52.6	37.6	36.0	49.6	56.2	55.8	40.0	37.6	51.6	58.5	58.0	41.7	40.2	54.9	62.1	61.6	44.4	50.4	48.4	49.1	42.1
CNK CCCT S.08.01	57.7	40.7	39.1	54.6	62.2	61.9	43.8	41.1	57.2	65.1	64.7	46.0	44.4	61.4	69.8	69.3	49.5	54.6	53.1	54.0	46.1
CNK CCCT S.08.02	63.4	45.0	43.2	59.9	68.1	67.6	48.2	45.3	62.5	71.0	70.5	50.4	48.6	66.8	75.8	75.2	54.0	60.3	58.3	59.3	50.6
CNK CCCT S.10.01	64.9	45.4	43.6	61.4	70.2	69.8	49.1	46.0	64.6	73.7	73.3	51.7	50.1	69.7	79.4	78.9	56.0	61.0	59.7	60.7	51.6
CNK CCCT S.10.02	71.7	50.6	48.6	67.8	77.3	76.9	54.5	51.1	71.1	80.9	80.4	57.1	55.2	76.4	86.8	86.2	61.5	67.9	66.1	67.1	57.2
CNK CCCT 2 x S.06.01	96.6	68.6	65.9	91.2	103.7	103.0	73.5	69.0	95.2	108.1	107.3	76.8	74.1	101.7	115.3	114.4	82.2	92.0	88.8	90.3	77.2
CNK CCCT 2 x S.06.02	105.2	75.2	72.1	99.2	112.5	111.6	80.1	75.2	103.2	117.0	116.0	83.4	80.3	109.7	124.2	123.1	88.9	100.7	96.8	98.3	84.1
CNK CCCT 2 x S.08.01	115.5	81.4	78.3	109.2	124.4	123.7	87.7	82.3	114.4	130.2	129.4	92.0	88.9	122.9	139.6	138.6	99.1	109.2	106.2	108.0	92.1
CNK CCCT 2 x S.08.02	126.7	90.0	86.4	119.7	136.1	135.2	96.4	90.5	125.0	142.0	141.0	100.8	97.2	133.6	151.5	150.3	108.0	120.6	116.7	118.5	101.3
CNK CCCT 2 x S.10.01	129.8	90.7	87.3	122.9	140.4	139.7	98.2	92.1	129.1	147.3	146.5	103.5	100.1	139.4	158.8	157.8	112.1	121.9	119.5	121.4	103.3
CNK CCCT 2 x S.10.02	143.5	101.1	97.2	135.7	154.6	153.7	108.9	102.2	142.1	161.8	160.8	114.3	110.4	152.7	173.5	172.3	123.1	135.7	132.1	134.2	114.5
CNK CCCT T.06.01	52.8	37.5	36.0	49.9	56.7	56.3	40.2	37.7	52.0	59.1	58.7	42.0	40.5	55.6	63.0	62.5	44.9	50.3	48.5	49.4	42.2
CNK CCCT T.06.02	57.5	41.1	39.4	54.2	61.5	61.1	43.8	41.1	56.4	64.0	63.5	45.6	43.9	60.0	67.9	67.3	48.6	55.1	53.0	53.8	46.0
CNK CCCT T.08.01	63.1	44.5	42.7	59.6	68.0	67.6	47.9	44.9	62.5	71.1	70.7	50.2	48.6	67.1	76.3	75.7	54.1	59.6	58.0	59.0	50.3
CNK CCCT T.08.02	69.3	49.2	47.2	65.4	74.4	73.9	52.7	49.5	68.3	77.6	77.0	55.1	53.1	73.0	82.8	82.2	59.0	65.9	63.8	64.8	55.4
CNK CCCT T.10.01	70.8	49.5	47.6	67.1	76.6	76.2	53.6	50.3	70.5	80.4	80.0	56.5	54.6	76.1	86.7	86.1	61.2	66.6	65.2	66.2	56.4
CNK CCCT T.10.02	78.4	55.2	53.1	74.1	84.5	84.0	59.5	55.8	77.6	88.4	87.8	62.4	60.3	83.4	94.8	94.1	67.2	74.1	72.2	73.3	62.5
CNK CCCT 2 x T.06.01	105.6	75.0	72.0	99.7	113.3	112.6	80.3	75.4	104.1	118.2	117.3	84.0	81.0	111.2	126.1	125.1	89.9	100.6	97.1	98.8	84.4
CNK CCCT 2 x T.06.02	115.0	82.2	78.8	108.5	123.1	122.1	87.6	82.3	112.9	127.9	126.9	91.3	87.8	120.0	135.9	134.7	97.2	110.2	105.9	107.5	92.0
CNK CCCT 2 x T.08.01	126.1	88.9	85.5	119.3	135.9	135.1	95.8	89.9	125.0	142.2	141.3	100.5	97.1	134.2	152.5	151.4	108.2	119.3	116.0	118.0	100.6
CNK CCCT 2 x T.08.02	138.5	98.3	94.4	130.8	148.8	147.8	105.4	98.9	136.6	155.2	154.1	110.2	106.3	146.0	165.6	164.3	118.0	131.8	127.6	129.6	110.7
CNK CCCT 2 x T.10.01	141.6	99.0	95.2	134.1	153.2	152.5	107.2	100.5	140.9	160.8	159.9	112.9	109.3	152.2	173.3	172.3	122.3	133.1	130.4	132.5	112.7
CNK CCCT 2 x T.10.02	156.7	110.5	106.2	148.2	168.9	167.9	119.0	111.6	155.3	176.7	175.6	124.8	120.6	166.8	189.5	188.2	134.4	148.2	144.3	146.6	125.0
CNK CCCT U.06.01	57.4	40.8	39.2	54.2	61.6	61.2	43.7	41.0	56.6	64.2	63.8	45.6	44.0	60.4	68.5	68.0	48.9	54.7	52.8	53.7	45.9
CNK CCCT U.06.02	62.6	44.7	42.9	59.0	66.9	66.4	47.6	44.7	61.4	69.6	69.0	49.6	47.8	65.3	73.9	73.2	52.9	59.9	57.6	58.5	50.0
CNK CCCT U.08.01	68.5	48.3	46.4	64.8	73.8	73.4	52.0	48.8	67.9	77.2	76.8	54.6	52.7	72.9	82.8	82.3	58.8	64.8	63.0	64.1	54.7
CNK CCCT U.08.02	75.3	53.4	51.3	71.1	80.9	80.3	57.3	53.8	74.2	84.3	83.7	59.9	57.8	79.4	90.0	89.3	64.1	71.7	69.3	70.4	60.2
CNK CCCT U.10.01	76.9	53.8	51.7	72.8	83.2	82.8	58.2	54.6	76.5	87.3	86.8	61.3	59.3	82.6	94.1	93.5	66.4	72.3	70.8	71.9	61.2
CNK CCCT U.10.02	85.1	60.0	57.7	80.5	91.7	91.2	64.6	60.6	84.3	96.0	95.4	67.8	65.5	90.6	102.9	102.2	73.0	80.5	78.4	79.6	67.9
CNK CCCT 2 x U.06.01	114.8	81.6	78.3	108.4	123.2	122.4	87.3	82.0	113.1	128.5	127.5	91.3	88.0	120.9	137.0	135.9	97.7	109.3	105.5	107.3	91.8
CNK CCCT 2 x U.06.02	125.1	89.4	85.7	118.0	133.8	132.8	95.3	89.5	122.8	139.2	138.0	99.3	95.5	130.5	147.8	146.5	105.7	119.8	115.2	116.9	100.1
CNK CCCT 2 x U.08.01	137.0	96.6	92.9	129.6	147.7	146.8	104.0	97.6	135.7	154.5	153.5	109.1	105.5	145.8	165.7	164.5	117.5	129.6	126.0	128.2	109.3
CNK CCCT 2 x U.08.02	150.6	106.9	102.6	142.2	161.7	160.6	114.5	107.5	148.5	168.7	167.5	119.7	115.5	158.7	180.0	178.6	128.3	143.3	138.6	140.8	120.3
CNK CCCT 2 x U.10.01	153.8	107.5	103.4	145.6	166.3	165.5	116.4	109.1	153.0	174.6	173.6	122.6	118.6	165.2	188.2	187.0	132.8	144.5	141.6	143.8	122.4
CNK CCCT 2 x U.10.02	170.2	120.0	115.3	161.0	183.5	182.4	129.2	121.2	168.6	192.0	190.8	135.6	131.0	181.2	205.9	204.4	146.0	161.0	156.8	159.2	135.8
SP CNK CCCT U8-II	80.5	57.2	54.9	76.0	86.4	85.8	61.2	57.5	79.3	90.1	89.4	64.0	61.7	84.8	96.1	95.3	68.5	76.6	74.0	75.3	64.3