



# COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068  
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

**Dongguan Ryoden Cooling Equipment Co.,Ltd.**  
**RTM-L Series CTI Certified Closed-Circuit Cooling Towers**  
**(With Water as the Process Fluid)**  
**CTI Certification Validation Number C71B-15R00**  
**September 2, 2015 (Revision 0)**

RTM-20L-C1	RTM-85L-C1
RTM-30L-C1	RTM-100L-C1
RTM-40L-C1	RTM-125L-C1
RTM-50L-C1	RTM-150L-C1
RTM-60L-C1	RTM-175L-C1
RTM-70L-C1	

#### Footnotes:

1. Multiple cell configurations of the single cell models above are also available but not listed individually. Multi-cell configurations are end-wall to end-wall arrangements of the single cell designs which do not impact the air flow rate or capacity of the individual cells, and are included in the certification. See example model number below.
2. Certification includes galvanized steel plate or stainless steel plate structure materials and PVC or glass fiber reinforced casing materials.
3. Certification includes optional items that do not affect thermal performance, for example, access ladder and handrails.
4. Certified Model Number Example: RTM-100L-C1 x 2  
RTM – Line Designation  
100 – Unit Model Number  
L – Low Noise  
C1 – Single Fan Type  
'x 2' – Two cell arrangement of the primary certified model (capacity equals 2 times rated capacity)