



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • <http://www.cti.org>

E.W. Gohl GmbH
DTC ecoTec Line of CTI Certified Cooling Towers
CTI Certification Validation Number C92A-14R01
February 6, 2015 (Revision 1)

NOC 01

NOC 02

NOC 03

NOC 04

Footnotes:

1. The Gohl DTC ecoTec line of cooling towers has also received Eurovent Certita Certification (ECC) Certification Diploma N° : 14.09.002 on September 9, 2014 (revised February 2, 2015). See <http://www.eurovent-certification.com> for additional information.
2. For Standard models, the casing panels are made of galvanized steel with Gohl whirl sintering protection (min. 0.3mm coating thickness on each panel side). Optional stainless steel panels in 1.4301 / 1.4571 are also available.