



# COOLING TECHNOLOGY INSTITUTE

P. O. Box 73383, Houston, Texas 77273 • 2611 FM 1960 West, Suite A-101, Houston, Texas 77068  
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

**Guangzhou Laxun Technology Exploit Co., Ltd.**  
**LMB Line of CTI Certified Induced-draft, Closed-Circuit Cooling Towers**  
**CTI Certification Validation Number 12-45-02**  
**December 28, 2013 (Revision 1)**

LMB-50

LMB-60

LMB-80

LMB-100

LMB-110

LMB-125

LMB-150

LMB-175

LMB-200

---

Footnotes:

1. Certification applies only to units with water as the process fluid and copper heat exchangers.
2. Multiple cell models of the single cell models above are also available but not listed.
3. Certification includes unit with optional gear drive in place of standard belt drive.
4. Certification includes tower construction materials indicated by suffixes -G, -S, -FG and -FS which are added to basic model numbers above where:
  - G is for HDG casing, basin, mainframe and hardware
  - S is for stainless steel casing, basin, mainframe and hardware
  - FG is for FRP casing, FRP basin and HDG mainframe and hardware
  - FS is for FRP casing, FRP basin and stainless steel mainframe and hardware
5. Sample model number: LMB-80-G-\_\_  
Where: LMB = The product series  
-80 = The capacity or nominal flow rate  
-G = HDG casing, basin, mainframe and hardware