



# COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068  
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

**King Sun Industry Company, Ltd.**  
**KC Line of CTI Certified Closed-Circuit Cooling Towers**  
**With Water as the Process Fluid**  
**CTI Certification Validation Number C35C-11R01**  
**December 11, 2015 (Revision 1)**

KC-80  
KC-100  
KC-125  
KC-150  
KC-175  
KC-200  
KC-225  
KC-250  
KC-300

## Footnotes:

1. Multiple cell configurations of the single cell models above are also available but not listed individually. Multi-cell configurations are end-wall to end-wall arrangements of the single cell designs which do not impact the air flow rate or capacity of the individual cells, and are included in the certification.
2. The CTI Certification applies to units using water as the process fluid.
3. Certification includes optional items that do not affect thermal performance, for example, access ladder and handrails.
4. Suffix 'X' is affixed to model numbers of units that are not CTI Certified, due either to application or customer-required product accessories or modifications.

Certified Model Number Example: KC-200-02

- KC – Line Designation
- 200– Model Number and relative size
- -02 – Two cell arrangement of the primary certified model (capacity equals 2 times rated capacity)

Note: One cell: KC-200, Two Cell: KC-200-02, Three Cell: KC-200-03, etc.