

STD-201RS Table 3b - SI Units - Cooling Towers (CT)

Condition Reference #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
Wet Bulb °C	10	10	10	10	10	13	13	13	13	13	16	16	16	16	16	18	18	18	18	18	21	21
Range °C	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6
Approach °C	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6
Inlet Water Temperature °C	20	22	23	22	25	23	25	26	25	28	26	28	29	28	31	28	30	31	30	33	31	33
Outlet Water Temperature °C	14	16	17	14	17	17	19	20	17	20	20	22	23	20	23	22	24	25	22	25	25	27
KFT-06062-GLG in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	6.88	10.18	11.96	5.68	9.69	8.14	12.00
KFT-06062-GLH in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	7.88	11.66	13.69	6.50	11.10	9.31	13.73
KFT-06062-GLK in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	9.34	13.82	16.23	7.70	13.16	11.04	16.28
KFT-06062-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	10.69	15.82	18.58	8.82	15.06	12.64	18.64
KFT-06063-GLG in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	8.09	11.72	13.66	6.75	11.22	9.51	13.74
KFT-06063-GLH in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	9.26	13.41	15.63	7.73	12.85	10.88	15.73
KFT-06063-GLK in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	10.98	15.90	18.54	9.16	15.23	12.90	18.65
KFT-06063-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	12.56	18.20	21.22	10.49	17.44	14.77	21.35
KFT-06063-GLM in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	13.83	20.03	23.35	11.54	19.19	16.26	23.50
KFT-07072-GLG in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	8.46	12.52	14.71	6.98	11.92	10.01	14.76
KFT-07072-GLH in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	9.69	14.34	16.84	7.99	13.65	11.46	16.89
KFT-07072-GLK in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	11.48	17.00	19.97	9.48	16.18	13.58	20.03
KFT-07072-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	13.15	19.46	22.86	10.85	18.53	15.55	22.93
KFT-07073-GLH in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	10.49	15.20	17.72	8.76	14.56	12.33	17.83
KFT-07073-GLK in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	12.44	18.02	21.01	10.38	17.26	14.62	21.13
KFT-07073-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	14.24	20.63	24.05	11.88	19.76	16.74	24.19
KFT-07073-GLM in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	15.67	22.71	26.47	13.08	21.75	18.43	26.63
KFT-08082-GLH in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	11.82	17.50	20.56	9.76	16.66	13.98	20.62
KFT-08082-GLK in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	14.02	20.75	24.37	11.57	19.75	16.58	24.45
KFT-08082-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	16.05	23.75	27.90	13.24	22.61	18.98	27.99
KFT-08082-GLM in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	17.66	26.14	30.71	14.58	24.89	20.89	30.80
KFT-08073-GLK in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	14.27	20.69	24.10	11.93	19.82	16.78	24.25
KFT-08073-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	16.34	23.68	27.59	13.66	22.69	19.21	27.76
KFT-08073-GLM in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	17.98	26.06	30.36	15.04	24.97	21.15	30.55
KFT-08073-GLN in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	20.58	29.84	34.76	17.21	28.59	24.21	34.97
KFT-08083-GLK in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	17.16	24.87	28.97	14.35	23.83	20.18	29.15
KFT-08083-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	19.64	28.47	33.17	16.43	27.28	23.10	33.37
KFT-08083-GLM in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	21.61	31.33	36.50	18.08	30.03	25.42	36.72
KFT-08083-GLN in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	24.74	35.87	41.79	20.70	34.37	29.10	42.04
KFT-08083-GLP in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	27.23	39.48	45.99	22.78	37.83	32.03	46.27
KFT-10102-GLK in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	18.57	27.49	32.30	15.33	26.18	21.97	32.39

STD-201RS Table 3b - SI Units - Cooling Towers (CT)

Condition Reference #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
Wet Bulb °C	10	10	10	10	10	13	13	13	13	13	16	16	16	16	16	18	18	18	18	18	21	21
Range °C	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6
Approach °C	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6
Inlet Water Temperature °C	20	22	23	22	25	23	25	26	25	28	26	28	29	28	31	28	30	31	30	33	31	33
Outlet Water Temperature °C	14	16	17	14	17	17	19	20	17	20	20	22	23	20	23	22	24	25	22	25	25	27
KFT-10102-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	21.26	31.47	36.97	17.55	29.97	25.15	37.08
KFT-10102-GLM in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	23.40	34.63	40.69	19.32	32.98	27.68	40.81
KFT-10102-GLN in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	26.79	39.65	46.58	22.11	37.75	31.68	46.72
KFT-10103-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	23.26	33.72	39.29	19.46	32.31	27.36	39.52
KFT-10103-GLM in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	25.60	37.12	43.24	21.41	35.56	30.11	43.50
KFT-10103-GLN in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	29.31	42.49	49.50	24.51	40.71	34.47	49.80
KFT-10103-GLP in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	32.26	46.77	54.48	26.98	44.81	37.94	54.81
KFT-12122-GLL in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	28.62	42.36	49.76	23.62	40.34	33.85	49.91
KFT-12122-GLM in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	31.50	46.62	54.77	26.00	44.39	37.25	54.94
KFT-12122-GLN in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	36.06	53.37	62.70	29.76	50.82	42.65	62.89
KFT-12122-GLP in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	39.69	58.74	69.00	32.76	55.93	46.94	69.21
KFT-12123-GLM in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	35.27	51.13	59.57	29.50	49.00	41.49	59.93
KFT-12123-GLN in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	40.38	58.53	68.19	33.77	56.09	47.50	68.61
KFT-12123-GLP in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	44.44	64.43	75.05	37.17	61.73	52.28	75.51
KFT-12123-GLR in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	47.87	69.40	80.85	40.04	66.50	56.31	81.34
KFT-15152-GLN in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	49.37	73.06	85.84	40.75	69.58	58.39	86.10
KFT-15152-GLP in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	54.34	80.42	94.47	44.85	76.58	64.26	94.77
KFT-15152-GLR in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	58.53	86.63	101.77	48.31	82.49	69.23	102.08
KFT-15152-GLT in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	62.20	92.06	108.15	51.34	87.66	73.56	108.48
KFT-18182-GLN in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	57.24	84.71	99.52	47.24	80.67	67.70	99.82
KFT-18182-GLP in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	63.00	93.24	109.54	52.00	88.79	74.51	109.87
KFT-18182-GLR in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	67.86	100.44	117.99	56.01	95.65	80.26	118.35
KFT-18182-GLT in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	72.12	106.73	125.39	59.52	101.64	85.29	125.77
KFT-18183-GLP in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	77.01	111.64	130.06	64.41	106.97	90.58	130.85
KFT-18183-GLR in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	82.96	120.26	140.10	69.39	115.23	97.58	140.96
KFT-18183-GLT in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	88.16	127.80	148.88	73.74	122.45	103.69	149.79
KFT-18183-GLU in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	97.03	140.66	163.86	81.16	134.78	114.13	164.86
KFT-20202-GLP in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	73.11	108.20	127.11	60.34	103.03	86.46	127.50
KFT-20202-GLR in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	78.75	116.55	136.92	65.00	110.99	93.14	137.34
KFT-20202-GLT in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	83.68	123.85	145.50	69.07	117.94	98.97	145.94
KFT-20202-GLU in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	92.11	136.32	160.14	76.02	129.81	108.93	160.63

STD-201RS Table 3b - SI Units - Cooling Towers (CT)

Condition Reference #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
Wet Bulb °C	10	10	10	10	10	13	13	13	13	13	16	16	16	16	16	18	18	18	18	18	21	21
Range °C	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6	6	8	8	6	6
Approach °C	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6	7	4	7	4	6
Inlet Water Temperature °C	20	22	23	22	25	23	25	26	25	28	26	28	29	28	31	28	30	31	30	33	31	33
Outlet Water Temperature °C	14	16	17	14	17	17	19	20	17	20	20	22	23	20	23	22	24	25	22	25	25	27
KFT-20203-GLR in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	96.38	139.71	162.76	80.61	133.87	113.36	163.75
KFT-20203-GLT in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	102.42	148.47	172.96	85.66	142.26	120.46	174.01
KFT-20203-GLU in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	112.72	163.41	190.37	94.28	156.57	132.58	191.52
KFT-20203-GLV in l/s	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	121.43	176.03	205.06	101.56	168.66	142.82	206.31

STD-201RS Table 3b - SI Units

Condition Reference #	23	24	25	26	27	28	29	30	31	32	33	34	35
Wet Bulb °C	21	21	21	24	24	24	24	24	27	27	27	27	27
Range °C	6	8	8	6	6	6	8	8	6	6	6	8	8
Approach °C	7	4	7	4	6	7	4	7	4	6	7	4	7
Inlet Water Temperature °C	34	33	36	34	36	37	36	39	37	39	40	39	42
Outlet Water Temperature °C	28	25	28	28	30	31	28	31	31	33	34	31	34
KFT-06062-GLG in l/s	14.08	6.74	11.47	9.66	14.19	16.63	8.03	13.60	11.49	16.82	19.69	9.60	16.18
KFT-06062-GLH in l/s	16.12	7.72	13.13	11.06	16.24	19.04	9.19	15.57	13.16	19.26	22.54	10.98	18.52
KFT-06062-GLK in l/s	19.11	9.15	15.56	13.11	19.26	22.57	10.89	18.46	15.60	22.83	26.73	13.02	21.96
KFT-06062-GLL in l/s	21.87	10.47	17.81	15.01	22.05	25.84	12.47	21.13	17.86	26.13	30.60	14.91	25.14
KFT-06063-GLG in l/s	16.00	7.98	13.20	11.22	16.15	18.78	9.45	15.58	13.28	19.05	22.12	11.23	18.43
KFT-06063-GLH in l/s	18.31	9.13	15.11	12.84	18.49	21.50	10.82	17.83	15.20	21.81	25.33	12.86	21.09
KFT-06063-GLK in l/s	21.71	10.82	17.92	15.22	21.92	25.49	12.83	21.14	18.02	25.86	30.03	15.25	25.01
KFT-06063-GLL in l/s	24.85	12.39	20.51	17.42	25.10	29.18	14.68	24.20	20.62	29.60	34.37	17.45	28.63
KFT-06063-GLM in l/s	27.35	13.64	22.57	19.18	27.62	32.11	16.16	26.64	22.70	32.58	37.83	19.21	31.51
KFT-07072-GLG in l/s	17.32	8.29	14.10	11.88	17.45	20.45	9.87	16.73	14.14	20.69	24.22	11.80	19.90
KFT-07072-GLH in l/s	19.82	9.49	16.14	13.60	19.98	23.42	11.30	19.15	16.18	23.69	27.73	13.51	22.78
KFT-07072-GLK in l/s	23.50	11.26	19.14	16.13	23.69	27.76	13.40	22.71	19.19	28.08	32.88	16.02	27.01
KFT-07072-GLL in l/s	26.91	12.89	21.91	18.46	27.12	31.78	15.34	26.00	21.96	32.15	37.63	18.34	30.92
KFT-07073-GLH in l/s	20.75	10.35	17.13	14.55	20.96	24.37	12.26	20.21	17.22	24.72	28.70	14.57	23.91
KFT-07073-GLK in l/s	24.61	12.27	20.31	17.25	24.85	28.89	14.54	23.96	20.42	29.30	34.03	17.28	28.35
KFT-07073-GLL in l/s	28.17	14.04	23.24	19.75	28.44	33.07	16.64	27.43	23.37	33.54	38.95	19.78	32.45
KFT-07073-GLM in l/s	31.00	15.46	25.58	21.73	31.31	36.40	18.32	30.19	25.73	36.92	42.87	21.77	35.72
KFT-08082-GLH in l/s	24.20	11.59	19.70	16.60	24.39	28.58	13.79	23.38	19.75	28.91	33.84	16.49	27.81
KFT-08082-GLK in l/s	28.69	13.74	23.36	19.68	28.91	33.89	16.35	27.72	23.42	34.28	40.13	19.55	32.97
KFT-08082-GLL in l/s	32.84	15.73	26.74	22.53	33.10	38.79	18.72	31.73	26.81	39.24	45.93	22.38	37.74
KFT-08082-GLM in l/s	36.15	17.31	29.43	24.80	36.43	42.69	20.60	34.92	29.50	43.19	50.56	24.63	41.54
KFT-08073-GLK in l/s	28.21	14.09	23.31	19.81	24.07	33.14	16.70	27.49	23.45	33.60	39.02	19.84	32.52
KFT-08073-GLL in l/s	32.30	16.13	26.69	22.67	27.55	37.94	19.12	31.47	26.84	38.47	44.67	22.71	37.23
KFT-08073-GLM in l/s	35.55	17.75	29.37	24.95	30.32	41.76	21.04	34.64	29.54	42.34	49.16	24.99	40.98
KFT-08073-GLN in l/s	40.69	20.32	33.62	28.56	34.71	47.80	24.09	39.65	33.82	48.46	56.28	28.61	46.91
KFT-08083-GLK in l/s	33.92	16.94	28.03	23.81	34.27	39.85	20.08	33.06	28.19	40.40	46.92	23.85	39.10
KFT-08083-GLL in l/s	38.83	19.39	32.09	27.26	39.23	45.61	22.99	37.84	32.27	46.24	53.70	27.30	44.76
KFT-08083-GLM in l/s	42.74	21.34	35.32	30.00	43.18	50.20	25.30	41.65	35.51	50.90	59.11	30.05	49.26
KFT-08083-GLN in l/s	48.92	24.43	40.43	34.34	49.43	57.47	28.96	47.68	40.65	58.26	67.66	34.40	56.39
KFT-08083-GLP in l/s	53.85	26.89	44.49	37.80	54.40	63.25	31.88	52.47	44.75	64.13	74.47	37.86	62.07
KFT-10102-GLK in l/s	38.02	18.20	30.96	26.08	38.31	44.90	21.67	36.73	31.03	45.42	53.17	25.90	43.69

STD-201RS Table 3b - SI Units

Condition Reference #	23	24	25	26	27	28	29	30	31	32	33	34	35
Wet Bulb °C	21	21	21	24	24	24	24	24	27	27	27	27	27
Range °C	6	8	8	6	6	6	8	8	6	6	6	8	8
Approach °C	7	4	7	4	6	7	4	7	4	6	7	4	7
Inlet Water Temperature °C	34	33	36	34	36	37	36	39	37	39	40	39	42
Outlet Water Temperature °C	28	25	28	28	30	31	28	31	31	33	34	31	34
KFT-10102-GLL in l/s	43.52	20.84	35.44	29.85	43.86	51.40	24.81	42.04	35.52	51.99	60.87	29.65	50.01
KFT-10102-GLM in l/s	47.90	22.93	39.00	32.86	48.27	56.57	27.30	46.28	39.10	57.23	66.99	32.64	55.04
KFT-10102-GLN in l/s	54.83	26.25	44.65	37.61	55.26	64.76	31.25	52.97	44.76	65.51	76.69	37.36	63.01
KFT-10103-GLL in l/s	45.99	22.97	38.01	32.28	46.47	54.03	27.23	44.82	38.22	54.78	63.61	32.34	53.02
KFT-10103-GLM in l/s	50.62	25.28	41.83	35.53	51.15	59.47	29.97	49.33	42.07	60.29	70.01	35.59	58.36
KFT-10103-GLN in l/s	57.95	28.94	47.89	40.68	58.55	68.07	34.31	56.47	48.15	69.02	80.15	40.74	66.80
KFT-10103-GLP in l/s	63.78	31.85	52.71	44.77	64.44	74.92	37.76	62.16	53.00	75.96	88.21	44.84	73.52
KFT-12122-GLL in l/s	58.57	28.05	47.70	40.18	59.03	69.18	33.39	56.59	47.81	69.99	81.93	39.91	67.36
KFT-12122-GLM in l/s	64.47	30.87	52.50	44.23	64.97	76.15	36.75	62.29	52.63	77.03	90.17	43.93	74.14
KFT-12122-GLN in l/s	73.80	35.34	60.10	50.63	74.38	87.16	42.07	71.30	60.24	88.18	103.22	50.29	84.87
KFT-12122-GLP in l/s	81.23	38.89	66.15	55.72	81.86	95.94	46.30	78.47	66.30	97.05	113.61	55.35	93.41
KFT-12123-GLM in l/s	69.74	34.83	57.63	48.96	70.47	81.93	41.29	67.97	57.96	83.06	96.46	49.04	80.40
KFT-12123-GLN in l/s	79.84	39.87	65.98	56.04	80.67	93.79	47.26	77.80	66.34	95.08	110.42	56.13	92.03
KFT-12123-GLP in l/s	87.87	43.88	72.61	61.68	88.78	103.22	52.02	85.63	73.02	104.65	121.53	61.78	101.29
KFT-12123-GLR in l/s	94.65	47.27	78.22	66.44	95.64	111.19	56.03	92.24	78.66	112.73	130.92	66.55	109.11
KFT-15152-GLN in l/s	101.04	48.38	82.28	69.32	101.83	119.34	57.60	97.62	82.48	120.72	141.33	68.85	116.12
KFT-15152-GLP in l/s	111.21	53.25	90.56	76.29	112.08	131.35	63.39	107.44	90.78	132.87	155.55	75.78	127.80
KFT-15152-GLR in l/s	119.80	57.36	97.56	82.18	120.73	141.49	68.29	115.74	97.79	143.13	167.56	81.64	137.67
KFT-15152-GLT in l/s	127.30	60.96	103.67	87.33	128.30	150.36	72.57	122.99	103.92	152.10	178.06	86.75	146.30
KFT-18182-GLN in l/s	117.15	56.09	95.40	80.36	118.07	138.37	66.78	113.18	95.63	139.97	163.86	79.83	134.63
KFT-18182-GLP in l/s	128.94	61.74	105.00	88.45	129.95	152.29	73.50	124.57	105.25	154.06	180.35	87.86	148.18
KFT-18182-GLR in l/s	138.90	66.51	113.11	95.28	139.98	164.05	79.18	134.19	113.38	165.95	194.28	94.65	159.62
KFT-18182-GLT in l/s	147.60	70.67	120.19	101.25	148.75	174.33	84.14	142.60	120.48	176.35	206.45	100.58	169.62
KFT-18183-GLP in l/s	152.26	76.04	125.83	106.88	153.85	178.87	90.14	148.39	126.53	181.34	210.60	107.06	175.53
KFT-18183-GLR in l/s	164.02	81.91	135.55	115.14	165.73	192.69	97.10	159.85	136.30	195.35	226.86	115.33	189.08
KFT-18183-GLT in l/s	174.30	87.05	144.04	122.35	176.12	204.76	103.19	169.86	144.85	207.59	241.07	122.55	200.93
KFT-18183-GLU in l/s	191.84	95.81	158.54	134.67	193.84	225.37	113.57	186.96	159.42	228.48	265.34	134.89	221.15
KFT-20202-GLP in l/s	149.62	71.64	121.84	102.64	150.79	176.72	85.29	144.55	122.13	178.77	209.28	101.96	171.94
KFT-20202-GLR in l/s	161.18	77.18	131.25	110.57	162.44	190.37	91.88	155.72	131.57	192.57	225.44	109.83	185.22
KFT-20202-GLT in l/s	171.28	82.01	139.48	117.49	172.61	202.29	97.63	165.47	139.81	204.64	239.56	116.71	196.83
KFT-20202-GLU in l/s	188.51	90.26	153.51	129.32	189.99	222.65	107.46	182.13	153.88	225.23	263.67	128.46	216.63

STD-201RS Table 3b - SI Units

Condition Reference #	23	24	25	26	27	28	29	30	31	32	33	34	35
Wet Bulb °C	21	21	21	24	24	24	24	24	27	27	27	27	27
Range °C	6	8	8	6	6	6	8	8	6	6	6	8	8
Approach °C	7	4	7	4	6	7	4	7	4	6	7	4	7
Inlet Water Temperature °C	34	33	36	34	36	37	36	39	37	39	40	39	42
Outlet Water Temperature °C	28	25	28	28	30	31	28	31	31	33	34	31	34
KFT-20203-GLR in l/s	190.55	95.16	157.47	133.76	192.53	223.85	112.81	185.69	158.35	226.94	263.54	133.98	219.66
KFT-20203-GLT in l/s	202.49	101.13	167.33	142.14	204.60	237.87	119.88	197.33	168.27	241.16	280.06	142.37	233.42
KFT-20203-GLU in l/s	222.87	111.30	184.17	156.44	225.19	261.81	131.94	217.19	185.21	265.43	308.24	156.70	256.92
KFT-20203-GLV in l/s	240.07	119.90	198.39	168.52	242.57	282.03	142.13	233.96	199.51	285.92	332.05	168.80	276.75

STD-201RS Table 3b - SI Units

Condition Reference #	36	37	38	39	40	41	42	43	44	45		46	47	48	49
Wet Bulb °C	29	29	29	29	29	32	32	32	33	32		21	25.56	27	28
Range °C	6	6	6	8	8	6	6	6	7	8		5	5.56	5	5
Approach °C	4	6	7	4	7	4	6	7	8	7		6	3.89	5	4
Inlet Water Temperature °C	39	41	42	41	44	42.2	44.2	45.2	48.2	47.2		32	35.00	37	37
Outlet Water Temperature °C	33	35	36	33	36	36.2	38.2	39.2	41.2	39.2		27	29.44	32	32
KFT-06062-GLG in l/s	12.92	18.88	22.08	10.82	18.19	NC	NC	NC	NC	NC		13.76	10.94	16.02	13.78
KFT-06062-GLH in l/s	14.79	21.61	25.27	12.39	20.82	NC	NC	NC	NC	NC		15.75	12.43	18.33	15.77
KFT-06062-GLK in l/s	17.54	25.62	29.96	14.69	24.69	NC	NC	NC	NC	NC		18.67	14.78	21.74	18.70
KFT-06062-GLL in l/s	20.08	29.33	34.30	16.82	28.26	NC	NC	NC	NC	NC		21.38	16.87	24.88	21.40
KFT-06063-GLG in l/s	14.88	21.29	24.71	12.63	20.65	NC	NC	NC	NC	NC		15.61	12.65	18.14	15.75
KFT-06063-GLH in l/s	17.04	24.37	28.28	14.45	23.64	NC	NC	NC	NC	NC		17.86	14.38	20.77	18.03
KFT-06063-GLK in l/s	20.20	28.89	33.53	17.14	28.02	NC	NC	NC	NC	NC		21.18	17.10	24.62	21.38
KFT-06063-GLL in l/s	23.12	33.07	38.38	19.62	32.08	NC	NC	NC	NC	NC		24.25	19.51	28.18	24.48
KFT-06063-GLM in l/s	25.45	36.40	42.25	21.59	35.31	NC	NC	NC	NC	NC		26.69	21.64	31.02	26.94
KFT-07072-GLG in l/s	15.90	23.22	27.16	13.31	22.37	NC	NC	NC	NC	NC		16.92	13.46	19.70	16.95
KFT-07072-GLH in l/s	18.20	26.58	31.09	15.24	25.61	NC	NC	NC	NC	NC		19.37	15.29	22.55	19.40
KFT-07072-GLK in l/s	21.58	31.51	36.86	18.07	30.37	NC	NC	NC	NC	NC		22.97	18.18	26.74	23.00
KFT-07072-GLL in l/s	24.70	36.07	42.19	20.68	34.76	NC	NC	NC	NC	NC		26.29	20.75	30.60	26.33
KFT-07073-GLH in l/s	19.31	27.62	32.05	16.38	26.79	NC	NC	NC	NC	NC		20.25	16.29	23.53	20.44
KFT-07073-GLK in l/s	22.89	32.75	38.00	19.42	31.76	NC	NC	NC	NC	NC		24.00	19.38	27.90	24.23
KFT-07073-GLL in l/s	26.20	37.48	43.50	22.23	36.36	NC	NC	NC	NC	NC		27.48	22.12	31.94	27.74
KFT-07073-GLM in l/s	28.84	41.26	47.87	24.47	40.01	NC	NC	NC	NC	NC		30.24	24.52	35.16	30.53
KFT-08082-GLH in l/s	22.21	32.44	37.94	18.60	31.26	NC	NC	NC	NC	NC		23.65	18.61	27.52	23.68
KFT-08082-GLK in l/s	26.33	38.47	44.99	22.05	37.06	NC	NC	NC	NC	NC		28.04	22.13	32.63	28.07
KFT-08082-GLL in l/s	30.15	44.03	51.50	25.24	42.43	NC	NC	NC	NC	NC		32.09	25.26	37.36	32.13
KFT-08082-GLM in l/s	33.18	48.46	56.68	27.78	46.70	NC	NC	NC	NC	NC		35.32	28.01	41.11	35.37
KFT-08073-GLK in l/s	26.27	37.55	43.56	22.30	36.43	NC	NC	NC	NC	NC		27.54	22.21	32.02	27.81
KFT-08073-GLL in l/s	30.07	42.99	49.86	25.53	41.70	NC	NC	NC	NC	NC		31.53	25.36	36.65	31.83
KFT-08073-GLM in l/s	33.10	47.31	54.88	28.10	45.89	NC	NC	NC	NC	NC		34.70	28.10	40.34	35.03
KFT-08073-GLN in l/s	37.89	54.16	62.83	32.17	52.53	NC	NC	NC	NC	NC		39.73	31.93	46.18	40.10
KFT-08083-GLK in l/s	31.58	45.15	52.37	26.81	43.79	NC	NC	NC	NC	NC		33.11	26.70	38.49	33.43
KFT-08083-GLL in l/s	36.16	51.68	59.95	30.70	50.13	NC	NC	NC	NC	NC		37.91	30.49	44.06	38.27
KFT-08083-GLM in l/s	39.79	56.88	65.98	33.78	55.18	NC	NC	NC	NC	NC		41.72	33.79	48.50	42.12
KFT-08083-GLN in l/s	45.55	65.11	75.53	38.67	63.16	NC	NC	NC	NC	NC		47.76	38.39	55.52	48.21
KFT-08083-GLP in l/s	50.14	71.67	83.13	42.57	69.52	NC	NC	NC	NC	NC		52.57	42.57	61.10	53.06
KFT-10102-GLK in l/s	34.89	50.97	59.61	29.22	49.11	NC	NC	NC	NC	NC		37.15	29.39	43.24	37.20

STD-201RS Table 3b - SI Units

Condition Reference #	36	37	38	39	40	41	42	43	44	45		46	47	48	49
Wet Bulb °C	29	29	29	29	29	32	32	32	33	32		21	25.56	27	28
Range °C	6	6	6	8	8	6	6	6	7	8		5	5.56	5	5
Approach °C	4	6	7	4	7	4	6	7	8	7		6	3.89	5	4
Inlet Water Temperature °C	39	41	42	41	44	42.2	44.2	45.2	48.2	47.2		32	35.00	37	37
Outlet Water Temperature °C	33	35	36	33	36	36.2	38.2	39.2	41.2	39.2		27	29.44	32	32
KFT-10102-GLL in l/s	39.94	58.35	68.24	33.45	56.22	NC	NC	NC	NC	NC		42.53	33.57	49.50	42.58
KFT-10102-GLM in l/s	43.96	64.22	75.11	36.82	61.88	NC	NC	NC	NC	NC		46.80	37.19	54.48	46.87
KFT-10102-GLN in l/s	50.33	73.51	85.97	42.15	70.83	NC	NC	NC	NC	NC		53.58	42.26	62.36	53.65
KFT-10103-GLL in l/s	42.83	51.85	71.01	36.36	59.38	NC	NC	NC	NC	NC		44.90	35.85	52.19	45.33
KFT-10103-GLM in l/s	47.14	57.07	78.16	40.02	65.36	NC	NC	NC	NC	NC		49.42	39.75	57.45	49.89
KFT-10103-GLN in l/s	53.96	65.33	89.47	45.81	74.81	NC	NC	NC	NC	NC		56.57	45.17	65.76	57.11
KFT-10103-GLP in l/s	59.39	71.90	98.47	50.42	82.34	NC	NC	NC	NC	NC		62.27	50.09	72.38	62.86
KFT-12122-GLL in l/s	53.77	78.53	91.85	45.03	75.67	NC	NC	NC	NC	NC		57.24	44.84	66.63	57.32
KFT-12122-GLM in l/s	59.18	86.44	101.09	49.56	83.29	NC	NC	NC	NC	NC		63.00	49.73	73.33	63.08
KFT-12122-GLN in l/s	67.74	98.94	115.72	56.73	95.34	NC	NC	NC	NC	NC		72.12	56.50	83.94	72.21
KFT-12122-GLP in l/s	74.56	108.90	127.37	62.44	104.93	NC	NC	NC	NC	NC		79.38	62.65	92.39	79.48
KFT-12123-GLM in l/s	64.94	92.83	107.68	55.13	90.04	NC	NC	NC	NC	NC		68.09	55.14	79.14	68.73
KFT-12123-GLN in l/s	74.34	106.26	123.26	63.11	103.07	NC	NC	NC	NC	NC		77.94	62.69	90.60	78.68
KFT-12123-GLP in l/s	81.82	116.95	135.67	69.46	113.45	NC	NC	NC	NC	NC		85.78	69.47	99.72	86.60
KFT-12123-GLR in l/s	88.14	125.99	146.14	74.82	122.21	NC	NC	NC	NC	NC		92.41	74.50	107.42	93.28
KFT-15152-GLN in l/s	92.75	135.47	158.44	77.67	130.53	NC	NC	NC	NC	NC		98.74	77.36	114.93	98.87
KFT-15152-GLP in l/s	102.08	149.10	174.39	85.49	143.67	NC	NC	NC	NC	NC		108.68	85.78	126.50	108.82
KFT-15152-GLR in l/s	109.97	160.62	187.85	92.09	154.76	NC	NC	NC	NC	NC		117.07	91.99	136.27	117.22
KFT-15152-GLT in l/s	116.86	170.68	199.62	97.86	164.46	NC	NC	NC	NC	NC		124.40	97.46	144.80	124.57
KFT-18182-GLN in l/s	107.53	157.06	183.70	90.06	151.34	NC	NC	NC	NC	NC		114.48	89.69	133.25	114.63
KFT-18182-GLP in l/s	118.36	172.87	202.19	99.12	166.57	NC	NC	NC	NC	NC		126.00	99.46	146.66	126.17
KFT-18182-GLR in l/s	127.49	186.22	217.80	106.77	179.43	NC	NC	NC	NC	NC		135.73	106.66	157.99	135.91
KFT-18182-GLT in l/s	135.48	197.89	231.45	113.46	190.68	NC	NC	NC	NC	NC		144.23	113.00	167.89	144.43
KFT-18183-GLP in l/s	141.78	171.65	235.09	120.37	196.59	NC	NC	NC	NC	NC		148.65	120.11	172.80	150.06
KFT-18183-GLR in l/s	152.73	184.91	253.25	129.66	211.77	NC	NC	NC	NC	NC		160.13	128.81	186.14	161.65
KFT-18183-GLT in l/s	162.29	196.49	269.11	137.78	225.04	NC	NC	NC	NC	NC		170.16	136.46	197.80	171.78
KFT-18183-GLU in l/s	178.63	216.27	296.20	151.65	247.68	NC	NC	NC	NC	NC		187.29	151.33	217.71	189.07
KFT-20202-GLP in l/s	137.34	200.60	234.62	115.02	193.29	NC	NC	NC	NC	NC		146.21	115.93	170.19	146.40
KFT-20202-GLR in l/s	147.95	216.09	252.74	123.90	208.22	NC	NC	NC	NC	NC		157.50	124.32	183.33	157.71
KFT-20202-GLT in l/s	157.21	229.63	268.57	131.66	221.26	NC	NC	NC	NC	NC		167.37	131.71	194.82	167.59
KFT-20202-GLU in l/s	173.04	252.74	295.60	144.91	243.53	NC	NC	NC	NC	NC		184.21	146.06	214.42	184.46

STD-201RS Table 3b - SI Units

Condition Reference #	36	37	38	39	40	41	42	43	44	45		46	47	48	49
Wet Bulb °C	29	29	29	29	29	32	32	32	33	32		21	25.56	27	28
Range °C	6	6	6	8	8	6	6	6	7	8		5	5.56	5	5
Approach °C	4	6	7	4	7	4	6	7	8	7		6	3.89	5	4
Inlet Water Temperature °C	39	41	42	41	44	42.2	44.2	45.2	48.2	47.2		32	35.00	37	37
Outlet Water Temperature °C	33	35	36	33	36	36.2	38.2	39.2	41.2	39.2		27	29.44	32	32
KFT-20203-GLR in l/s	177.42	253.62	294.20	150.63	246.01	NC	NC	NC	NC	NC		186.03	150.09	216.24	187.79
KFT-20203-GLT in l/s	188.54	269.51	312.64	160.07	261.43	NC	NC	NC	NC	NC		197.68	159.01	229.79	199.56
KFT-20203-GLU in l/s	207.52	296.64	344.10	176.18	287.74	NC	NC	NC	NC	NC		217.58	176.33	252.92	219.64
KFT-20203-GLV in l/s	223.54	319.54	370.67	189.78	309.96	NC	NC	NC	NC	NC		234.38	189.10	272.45	236.60