



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Mesan Cooling Tower, Ltd.

MXC Series of CTI Certified Induced-draft, Closed-circuit Cooling Towers

CTI Certification Validation Number C26H-12R01

December 1, 2013 (Revision 1) – Letter Update April 26, 2016

MXC-01-3	MXC-02-4	MXC-03-5.5	MXC-04-7.5
MXC-01-4	MXC-02-5.5	MXC-03-7.5	MXC-04-11
MXC-01-5.5	MXC-02-7.5	MXC-03-11	MXC-04-15
MXC-05-7.5	MXC-06-11	MXC-07-11	MXC-08-11
MXC-05-11	MXC-06-15	MXC-07-15	MXC-08-15
MXC-05-15	MXC-06-18.5	MXC-07-18.5	MXC-08-18.5
		MXC-07-22	MXC-08-22
			MXC-08-30

Footnotes:

- 1) Multiple cell models of the single cell models above are also available but not listed.
- 2) Certification applies only to units with water as the process fluid and stainless steel heat exchangers.
- 3) Add suffix -S4 for SS304 or -S6 for SS316 stainless steel structural members & hardware
- 4) Add suffix -F4 for SS304 or -F6 for SS316 stainless steel casing, structural members & hardware
- 5) Add suffix-G for HDGS casing, structural members & hardware
- 6) Certification includes units with optional gear drive in place of standard belt drive.

Sample Model Number: MXC-01-3-S6-2 where:

MXC = product line name
-01 = box size designator
-3 = motor size, kW
S6 = SS316 structural members & hardware
-2 = number of cells