



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Ocean Cooling Tower Sdn Bhd YC Series CTI Certified Cooling Towers CTI Certification Validation Number C86A-17R00 August 8, 2017 (Revision 0)

YC-192024-5.5	YC-252828-7.5
YC-192324-5.5	YC-252828-11
YC-242628-5.5	YC-293225-11
YC-242628-7.5	YC-293229-11

See Footnotes, below

Footnotes:

1. Multiple cell configurations of the single cell models above are also available but not listed individually. Multi-cell configurations are end-wall to end-wall arrangements of the single cell designs which do not impact the air flow rate or capacity of the individual cells, and are included in the certification.
2. Line Designation 'YC' indicates standard external piping arrangement. Line Designation 'YCB' indicates optional internal piping arrangement.
3. Certification includes optional items that do not affect thermal performance, for example, access ladder and handrails.
4. Suffix '-X' is affixed to model numbers of units that are not CTI Certified, due either to application or product accessories or modifications.

Certified Model Number Examples:

YC-192324-5.5-2 YCB-192324-5.5-2

- YC/YCB – Line Designation
- 192324 – Model Number
- '-5.5' – Nominal Motor Size
- '-2' – Two cell arrangement of the primary certified model (capacity equals 2 times rated capacity)