



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Proficool FANS Sp. z o.o.
BORA Series of ECC Certified Cooling Towers
ECC Certification Diploma: 15.02.193
CTI Certification Validation Number C90A-15R00
June 1, 2015 (Revision 0)

| | | | |
|--------------------|---------------------|--------------------|--------------------|
| B-750/AB | B-3750/1,2/11B/AB | B-7500/1,2/37B/AB | B-750/FB |
| | B-3750/1,5/11B/AB | B-7500/1,5/37B/AB | |
| B-1250/AB | B-3750/1,2/15B/AB | B-7500/1,2/45B/AB | B-1250/FB |
| | B-3750/1,5/15B/AB | B-7500/1,5/45B/AB | |
| B-1600/1,2/3B/AB | B-3750/1,2/18,5B/AB | B-7500/1,2/55B/AB | B-1600/1,2/3B/FB |
| B-1600/1,2/4B/AB | B-3750/1,5/18,5B/AB | B-7500/1,5/55B/AB | B-1600/1,2/4B/FB |
| B-1600/1,2/5,5B/AB | B-3750/1,2/11/AB | B-7500/1,2/75B/AB | B-1600/1,2/5,5B/FB |
| B-1600/1,2/3/AB | B-3750/1,5/11/AB | B-7500/1,5/75B/AB | B-1600/1,2/3/FB |
| B-1600/1,2/4/AB | B-3750/1,2/15/AB | B-7500/1,2/37/AB | B-1600/1,2/4/FB |
| B-1600/1,2/5,5/AB | B-3750/1,5/15/AB | B-7500/1,5/37/AB | B-1600/1,2/5,5/FB |
| | B-3750/1,2/18,5/AB | B-7500/1,2/45/AB | |
| B-2400/1,2/4B/AB | B-3750/1,5/18,5/AB | B-7500/1,5/45/AB | |
| B-2400/1,2/5,5B/AB | | B-7500/1,2/55/AB | |
| B-2400/1,2/7,5B/AB | B-5000/1,2/18,5B/AB | B-7500/1,5/55/AB | |
| B-2400/1,2/11B/AB | B-5000/1,5/18,5B/AB | B-7500/1,2/75/AB | |
| B-2400/1,2/4/AB | B-5000/1,2/22B/AB | B-7500/1,5/75/AB | |
| B-2400/1,2/5,5/AB | B-5000/1,5/22B/AB | | |
| B-2400/1,2/7,5/AB | B-5000/1,2/30B/AB | B-10000/1,2/75/AB | |
| B-2400/1,2/11/AB | B-5000/1,5/30B/AB | B-10000/1,5/75/AB | |
| | B-5000/1,2/37B/AB | B-10000/1,2/90/AB | |
| B-3000/1,2/5,5B/AB | B-5000/1,5/37B/AB | B-10000/1,5/90/AB | |
| B-3000/1,2/7,5B/AB | B-5000/1,2/18,5/AB | B-10000/1,2/110/AB | |
| B-3000/1,2/11B/AB | B-5000/1,5/18,5/AB | B-10000/1,5/110/AB | |
| B-3000/1,2/15B/AB | B-5000/1,2/22/AB | B-10000/1,2/132/AB | |
| B-3000/1,2/5,5/AB | B-5000/1,5/22/AB | B-10000/1,5/132/AB | |
| B-3000/1,2/7,5/AB | B-5000/1,2/30/AB | | |
| B-3000/1,2/11/AB | B-5000/1,5/30/AB | | |
| B-3000/1,2/15/AB | B-5000/1,2/37/AB | | |
| | B-5000/1,5/37/AB | | |

See Footnote, Next Page



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Proficool FANS Sp. z o.o.
BORA Series of ECC Certified Cooling Towers
ECC Certification Diploma: 15.02.193
CTI Certification Validation Number C90A-15R00
June 1, 2015 (Revision 0)

Footnotes to Certified Model List:

1. Multi-cell configurations of the primary single cell models are certified with an adjustment of the leg height of all of the cells to permit more open area for the remaining, unblocked, inlets of interior cells. This option limits the impact on airflow rate or capacity of the individual cells.
2. Certification includes stainless steel structure and glass fiber reinforced casing materials.
3. Certification includes optional items that do not affect thermal performance, for example, access ladder and handrails.
4. Certified Model Number Example: B-XXXX/Y,Y/ZZ(B)/VV
 - B – BORA series
 - XXXX – Unit Model Number
 - Y,Y – Height of cooling fill in cooling tower
 - ZZ – Nominal motor power
 - (B) – B indicates execution with collective tray (basin)
 - VV – AB indicates adjustable blade execution while FB indicates fixed blade execution