



# COOLING TECHNOLOGY INSTITUTE

P. O. Box 73383, Houston, Texas 77273 • 2611 FM 1960 West, Suite A-101, Houston, Texas 77068  
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

**Ryowo (Holding) Company, Ltd.**  
**FVS Series Line of CTI Certified Cooling Towers**  
**CTI Certification Validation Number 12-27-06**  
**October 5, 2012 (Revision 0)**

<b>FVS-110</b>	<b>FVS-215</b>	<b>FVS-310</b>	<b>FVS-410</b>	<b>FVS-520</b>
<b>FVS-120</b>	<b>FVS-225</b>	<b>FVS-320</b>	<b>FVS-420</b>	<b>FVS-530</b>
<b>FVS-130</b>	<b>FVS-235</b>	<b>FVS-330</b>	<b>FVS-430</b>	<b>FVS-540</b>
<b>FVS-140</b>	<b>FVS-245</b>	<b>FVS-340</b>	<b>FVS-440</b>	<b>FVS-550</b>
<b>FVS-150</b>			<b>FVS-450</b>	<b>FVS-560</b>

#### Footnotes:

- Suffixes -GI, -SS, -AS, -AG are added to the basic model numbers listed above to indicate the tower construction materials or options:
  - GI for FRP casing, FRP basin and HDG structural members and hardware.
  - SS for FRP casing, FRP basin and stainless steel structural members and hardware.
  - AS for stainless steel casing, basin, structural members and hardware.
  - AG for HDG casing, basin, structural members and hardware.
- Suffixes /SLF, and /L are added to the basic model numbers to indicate optional parts:
  - /SLF is for basic models using super low noise fan.
  - /L is for basic models with additional louvers installed in front of air inlet faces.
- Certification includes units with optional gear drive in place of standard belt drive.
- Certification includes use of optional handrail and/or optional caged ladders.
- Multiple cell models of the single cell models above are also available but not listed.