



# COOLING TECHNOLOGY INSTITUTE

P. O. Box 73383, Houston, Texas 77273 • 2611 FM 1960 West, Suite A-101, Houston, Texas 77068  
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Shanghai Liang Chi Cooling Equipment Co., Ltd..  
LCM Line of CTI Certified Cooling Towers  
CTI Certification Validation Number C62A-14R00  
October 10, 2014 (Re-issued August 31, 2017)

LCM-80	LCM-200
LCM-100	LCM-225
LCM-125	LCM-250
LCM-150	LCM-300
LCM-175	LCM-350

#### Footnotes:

1. Multiple cell configurations of the single cell models above are also available but not listed individually. Multi-cell configurations are end-wall to end-wall arrangements of the single cell designs which do not impact the air flow rate or capacity of the individual cells, and are included in the certification. See example model number below.
2. Certification includes galvanized steel or stainless steel structural materials and PVC or glass fiber reinforced casing materials.
3. Certification includes optional items that do not affect thermal performance, for example, access ladder and handrails.
4. Certified Model Number Example: LCM-150-C2  
LCM – Line Designation  
150 – Model Number (flow capacity at rated conditions, see selection table for details)  
'C2' – Two cell arrangement of the primary certified model (capacity equals 2 times rated capacity)