



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
 Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Sinro Air-conditioning (Fogang) Co., Ltd.
 SC-B Series of CTI Certified Closed-Circuit, Cross-Flow, Cooling Towers
 CTI Certification Validation Number C37C-11R02
 November 26, 2014 (Revision 2)

SC-B5-A	SC-B10-B	SC-B20-D	SC-B30-D	SC-B40-E
SC-B50-D	SC-B60-D	SC-B70-E	SC-B80-E	SC-B90-E
SC-B100-F	SC-B125-G	SC-B150-G	SC-B175-G	SC-B200-G

Footnotes:

1. Certification includes optional 304 stainless steel structure and hardware, suffix -S
2. Certification includes optional 316 stainless steel structure and hardware, suffix -SS
3. Sample model number: SC-B100-F-SS-2-1
 Where: SC-B100 = Product line and primary-cell box size
 -F = Fan Motor Power Code (see table, below)
 -SS = Optional 316 stainless steel structure
 -2-1 = 2 cells of primary SC-B100-F model combined as 1 tower
4. Motor Power Code Definition:

Motor Power (kW)	Letter Code
1.1	A
2.2	B
3	C
4	D
5.5	E
7.5	F
11	G
15	H
18.5	I
22	J
30	K
37	L
45	M
55	N

5. Customized configurations and other design variations to meet customer requirements are indicated in the model designation by the suffix -X and are not included in the certification.