



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Qingdao VOFAT Air Conditioning Equipment Co., Ltd.
MF Series Line of CTI Certified Cooling Towers
CTI Certification Validation Number C82A-16R00
September 20, 2016

MF-1900L

MF-2200L

MF-2400L

MF-2600L

MF-2900C1L

MF-2900C2L

MF-3500C1L

MF-3500C2L

Footnotes:

1. Multi-cell configurations are end-wall to end-wall arrangements of the single cell designs which do not impact airflow rate or the capacity of the individual cells and are certified.
2. Certification includes galvanized steel plate or stainless steel plate structure materials and PVC or glass fiber reinforced casing materials.
3. Certification includes optional items that do not affect thermal performance, for example, access ladder and handrails.
4. The MF Series product line model designations are as follows:

Sample model number: MF-2600L-2

Where: MF = VOFAT, Cross-flow, Open, Cooling Tower

2600 = Model code

L = Low Noise

-2 = Number of Cells (note: omitted or -1 indicates single cell)