



COOLING TECHNOLOGY INSTITUTE

P. O. Box 681807, Houston, Texas 77268 • 3845 Cypress Creek Parkway, Ste 420, Houston, Texas 77068
Phone: 281.583.4087 • Fax: 281.537.1721 • email: vmanser@cti.org • http://www.cti.org

Zhejiang Dongjie Cooling Tower Co., Ltd.
DHC Line of CTI Certified Cooling Towers
CTI Certification Validation Number C63B-15R00
January 2, 2015 (Reissued: June 21, 2017)

DHC-100	DHC-200
DHC-125	DHC-225
DHC-150	DHC-250
DHC-175	DHC-300

Footnotes:

1. Multiple cell configurations of the single cell models above are also available but not listed individually. Multi-cell configurations are end-wall to end-wall arrangements of the single cell designs which do not impact the air flow rate or capacity of the individual cells, and are included in the certification. See example model number below.
2. Certification includes units with optional gear drive in place of standard belt drive.
3. Certification includes galvanized steel or stainless steel structural materials and PVC or glass fiber reinforced casing materials.
4. Certification includes optional items that do not affect thermal performance, for example, access ladder and handrails.
5. Certified Model Number Example: DHC-150x2
 - DHC – Line Designation
 - 150 – Model Number (unitless)
 - 'x2' – Two cell arrangement of the primary certified model (capacity equals 2 times rated capacity)